

illuminated exit sign to BCA requirements with direction arrow as required
emergency lighting to BCA requirements
fire extinguisher 2A : 40B(E) C/W sign over
smoke detector to AS 3786
36 Im fire hose reel to AS2441 provided in recessed or flush cabinet were located external refer to hydraulic consultant drawings for locations
to be located no more than 4.0m from an exit
electrical meterboard/distribution board
indicates door circulation space to AS1428.1