

Project Name: Sewerage Network Master Plan for the Weinam Creek PDA
Project No:



Sewerage Network Master Plan for the Weinam Creek PDA

Redland Bay, Qld

Project Name: Sewerage Network Master Plan for the Weinam Creek PDA
Project No:

Redland City Council

ABN 86 058 929 428

Bloomfield & Middle Streets Cleveland Q 4163

PO Box 21 Cleveland Q 4163 Australia

Telephone: (07) 3829 8999 Facsimile: (07) 3829 8765

Email: redland@redland.qld.gov.au

Redland City Council

This document is and shall remain the property of Redland City Council. The document may only be used for the purposes for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

WRITER TO COMPLETE TABLE BELOW FOR VERSION CONTROL PURPOSES

| Document Status | | | | | |
|-----------------|--------|-----------|--------------------|-----------|----------|
| Rev No. | Author | Reviewers | Approved for Issue | | |
| | | | Name | Signature | Date |
| 001 | J. May | D. Heape | - | - | 24/02/20 |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Table of Contents

| | |
|--|----|
| EXECUTIVE SUMMARY | 4 |
| 1 INTRODUCTION | 6 |
| 1.1 Purpose | 6 |
| 1.2 Background..... | 6 |
| 1.3 Relevant Reports | 6 |
| 2 METHODOLOGY | 7 |
| 2.1 Design Standards | 7 |
| 2.2 Hydraulic Modelling..... | 7 |
| 3 RESULTS | 9 |
| 3.1 Pumps and Pressure Mains | 9 |
| 3.2 Wet Wells..... | 9 |
| 3.3 Gravity Mains | 10 |
| 3.4 Emergency Storage | 10 |
| 3.5 Sewer Infrastructure Upgrades | 11 |
| 3.6 Timing of Construction | 11 |
| 4 CONCLUSION | 13 |
| 5 APPENDICES..... | 15 |
| Appendix 1. Weinam Creek PDA Master Plan..... | 16 |
| Appendix 2. Sewerage catchments servicing the Weinam Creek PDA..... | 17 |
| Appendix 3. Pump station modelling results for Weinam PDA..... | 18 |
| Appendix 4. Wet well modelling results for Weinam Creek PDA..... | 26 |
| Appendix 5. Gravity main modelling results for Weinam Creek PDA | 27 |
| Appendix 6. Emergency storage modelling results for Weinam Creek PDA | 33 |
| Appendix 7. Proposed sewer infrastructure upgrades for the Weinam Creek PDA..... | 36 |
| Appendix 8. Detailed capital cost estimate calculations and assumptions | 37 |

EXECUTIVE SUMMARY

The Weinam Creek Priority Development Area (PDA) is located in Redland Bay, on the Moreton Bay foreshore, within the Redland City Council (RCC) Local Government Area (LGA). The Economic Development Queensland (EDQ) Weinam Creek PDA Development Scheme has proposed a mixed-use master plan, the majority of which will be high density residential apartment living, with buildings up to 7 storeys in height. The ultimate population density for the development scheme has been estimated at 3,000 Equivalent Population (EP) by Redland Investment Corporation (RIC).

EDQ's Weinam Creek PDA planning density (3,000 EP) far exceeds that of RCC's Local Government Infrastructure Plan (LGIP) ultimate planning demands (approximately 1,096 EP). A detailed sewerage planning study was therefore undertaken to determine the impact that the additional loading will have on the local existing network, and to identify infrastructure upgrades necessary to achieve RCC's minimum design standards.

The hydraulic analysis identified that there is sufficient capacity within the SPS 132 catchment south of the development, to incorporate the additional Weinam PDA loading, up to the 2041 planning horizon. For the SPS 90 catchment north of the development however, insufficient capacity was identified at both the existing (2017/18) and 2041 planning horizon. A summary of the deficiencies and proposed upgrades to resolve this are as follows.

- Insufficient gravity main flow depth capacity was identified along Outride Street and Banana Street across all planning horizons. A 390 m, DN150, DN200 and DN225 duplication main is therefore required to satisfy RCC's relevant Design Standards (d/D flow depth @ 75% for proposed pipework).
- Insufficient pump flow capacity was identified at SPS 90 across all planning horizons. This was identified to be a rising main capacity issue, as opposed to a pump capacity issues. Therefore, an 800 m, DN225 pipe upgrade is required to satisfy RCC's relevant Design Standard (3 m/s maximum flow velocity). To limit the impact on the downstream catchment, a renewal of the pump set and wet well will also be required.
- Insufficient emergency storage capacity was identified for the SPS 90 catchment, across all planning horizons. A 41 kL storage upgrade is therefore required to satisfy RCC's relevant Design Standard (4 hours ADWF storage).

A capital cost estimate for the proposed SPS 90 catchment infrastructure upgrade regime is as follows. See Appendix 8 for detailed calculations and assumptions.

| Catchment | Proposed Infrastructure | \$ / Unit Rate | Capital Cost (\$) | Purpose |
|--------------|---|-------------------------------------|-------------------|--|
| SPS 90 | 800 m x DN2225 pressure main | \$440 / m | \$352k | Comply SEQ Code flow velocity and increase pump capacity |
| | Duty/assist pump renewal/adjustment | \$500 / kw + install \$5k | \$25k | Reduce flow to downstream catchment |
| | Well and internal pipework renewal | Nil | \$500k | Extend asset life and reduce risk of failure |
| | 41 kL offline ES tank | \$4,389 / kL | \$180k | Comply SEQ Code 4 hours ADWF retention |
| | 154 m x DN150 GM 172 m x DN200 GM 66 m x DN225 GM | \$594 / m \$726 / m \$796 / m | \$269k | Comply SEQ Code flow depth |
| TOTAL | | | \$1.326M | |

The approximate timing of construction for these items is as follows.

- Package 1, DN150/DN200/DN225 gravity main duplication required at approximately 500 EP growth upstream of Banana Street. It is estimated this package of works will be required between 2023 to 2025.
- Package 2, DN225 rising main upgrade, pump renewal, wet well renewal and offline emergency storage tank required at approximately 1,800 EP growth within the catchment, including population increase outside of the Weinam Creek PDA. It is estimated this packages of works will be required between 2025 to 2027.

It is therefore recommended the proposed augmentation works are undertaken prior to the identified EP trigger points above and detailed design works completed in the 2021/22 fiscal year.

1 INTRODUCTION

The Weinam Creek Priority Development Area (PDA) is located in Redland Bay, on the Moreton Bay foreshore, within the Redland City Council (RCC) Local Government Area (LGA). The total area of the PDA is estimated at 42 Hectares and is bounded by Weinam Street to the west, Moreton Bay to the east, Peel Street to the north, and Moores Road to the south.

The Economic Development Queensland (EDQ) Weinam Creek PDA Development Scheme has proposed a mixed-use master plan, the majority of which will be high density residential apartment living, with buildings up to 7 storeys in height. The ultimate population density for the development scheme has been estimated at 3,000 Equivalent Population (EP). Refer to Appendix 1 for an overview of the PDA.

EDQ's Weinam Creek PDA planning density (3,000 EP) far exceeds that of RCC's Local Government Infrastructure Plan (LGIP) ultimate planning demands (approximately 1,096 EP). Therefore, the PDA will likely have a significant impact on the capacity of the existing local sewerage network, triggering the need for a review on the infrastructure master plan for the relevant catchments.

1.1 Purpose

The purpose of this report is to quantify the impact of EDQ's Weinam Creek PDA planning demands on RCC's existing sewerage network, and associated trunk infrastructure master planning. This information will form part of the revised headworks charges for approved Development Applications (DA), within the Weinam Creek PDA.

The hydraulic modelling was completed up to the 2041 planning horizon, to align with the Redland City Plan (2018) strategic framework. The 2016 Netserv Plan (and associated Sewerage Master Plan) were completed to a 2036 planning horizon to ensure compliance with minimum 20-year planning criteria required under the South-East Queensland Water (Distribution and Retail Restructuring) Act 2009.

1.2 Background

The Weinam Creek PDA is serviced by two sewer catchments, i.e. SPS 132 servicing the PDA south of Weinam Creek, and SPS 90 servicing the PDA north of Weinam Creek. Both pump stations are a 'duty/assist' arrangement, with SPS132 possessing 1 x 27 kW and 1 x 30 kW pumps, and SPS 90 possessing 2 x 18 kW pumps.

SPS 132 and SPS 90 boost sewage west and discharge to the SPS 67 gravity pipe network, which is subsequently transferred to the Victoria Point Sewage Treatment Plant (STP). Within the PDA, the sewer reticulation gravity network consists of PVC and AC DN150 and DN225 gravity mains. Refer to Appendix 2 for an overview of the existing network.

RCC's current LGIP considers augmentations and demand projections up to 2036, which identified no upgrades required to achieve design standards from SPS 132 and SPS 90, to SPS 67.

1.3 Relevant Reports

- The '*Redland Water Sewer Network Master Plan*' (Aug 2016) report presents information on augmentations to support RCC's LGIP for sewerage.
- The '*SEQ Water Supply and Sewerage Design and Construction Code (SEQ WS&S D&C Code)*' (2020) report presents RCC latest design standards.

2 METHODOLOGY

2.1 Design Standards

The design standards of the “*South East Queensland Water Supply and Sewerage Design and Construction Code*” (2020) were utilised for the assessment. A summary of the most relevant requirements are as follows.

Table 2-1. SEQ WS&S D&C Code provisions relevant to the analysis

| Provision | Specification |
|--|--|
| ET to EP conversion factor | 2.7 |
| Average Dry Weather Flow (ADWF) | 210 L/EP/day |
| Peak Wet Weather Flow (PWWF) | 5 x ADWF |
| Single pump capacity | C1 x ADWF (L/s) where; C1 = 3.5 to 5.0 C1 = 15 x (EP) ^{-0.1587} |
| Pump station operational storage (m ³) | 0.9 x Q / N where; Q = Single pump capacity (L/s) N = Number of pump starts per hour, where N = 12 for duty pump motor < 100 kW N = 8 for duty pump motor 100 – 200 kW N = 5 for duty pump motor > 200 kW |
| Pump station emergency storage (m ³) | 4 hours ADWF |
| Total pump station capacity (L/s) | PWWF |
| Maximum depth of gravity flow (proposed system) | 75% pipe diameter |
| Maximum depth of gravity flow (existing system) | 1.0 m below manhole level |
| Minimum rising main flow velocity | 0.75 m/s |
| Maximum rising main flow velocity | 3.0 m/s |

2.2 Hydraulic Modelling

The methodology adopted for the Weinam Creek PDA sewerage master plan study is as follows.

1. RCC’s Mike Urban LGIP sewer hydraulic model (VP72.3.8.4) was adopted for the hydraulic analysis. For the post-development scenario, RCC’s existing LGIP planning demands were removed from the model and EDQ’s Weinam Creek PDA planning demands (3,000 EP total) were allocated to relevant model nodes, on a lot by lot basis. The analysis was undertaken at the existing (2017/18) and 2041 planning horizon scenarios.
2. The pump capacity of SPS 90 and SPS 132 was assessed by comparing the PWWF required to service the catchment, pre- and post-development, to available pump flow capacities presented in the hydraulic model and corporate records. In addition, dynamic model runs were undertaken to confirm findings via review of the wet well depth profiles.

If the combined pump capacity was above the catchment’s PWWF, relevant design standards were achieved. If it was below the PWWF, network upgrades were investigated until compliance was attained, up to SPS 67.

Note: A pump capacity assessment of SPS 67 was not undertaken as part of this study, as an independent assessment was previously completed as part of the South-west Victoria Point Local Area Plan (LAP).

3. The wet well operational storage of SPS 90 and SPS 132 was subsequently evaluated by comparing the required operational storage capacity, pre- and post-development, against the operational volumes between duty pump start/stop levels.

If the wet well's operational storage volume was above the minimum requirement, compliance was achieved. If it was below the minimum requirement, upgrades were investigated until design standards were achieved.

4. The flow depth of the gravity main network servicing the PDA was assessed at pre- and post-development PWWF. To avoid surcharging from unrelated issues downstream, pumps were deactivated from the model and gravity mains discharged directly to a wet well outlet.

If flow depths could not be maintained within RCC specifications, pipe augmentations were investigated until design standards were achieved.

5. The emergency storage capacity of the SPS 90 and SPS 132 catchments was assessed by determining the ADWF retention time, pre- and post-development. This was achieved by priming the hydraulic model with ADWF and simulating a pump shutdown at the duty pump start level. Using the wet well depth profiles, the time duration from pump shutdown to the overflow event was used to determine the sewage retention time.

If the overflow event occurred at a duration beyond 4 hours, compliance was achieved. If it was below 4 hours, compliance was not achieved and storage upgrades were investigated.

6. Modelling results were reviewed and findings reported.

3 RESULTS

3.1 Pumps and Pressure Mains

A pump capacity assessment was undertaken on SPS 90 and SPS 132 as per the methodology described in Section 2.2 of this report. Refer to Table 3-1 below for a summary of results.

Table 3-1. Pump capacity modelling results for combined duty/assist flow rates (post-develop.)

| SPS | Combined Pump Flow Capacity | 2017 Flow Capacity Required (post-develop.) | 2041 Flow Capacity Required (post-develop.) |
|---------|-----------------------------|---|---|
| SPS 90 | 44 L/s | 48.5 L/s | 53.2 L/s |
| SPS 132 | 50 L/s | 23.5 L/s | 25.0 L/s |

The above results demonstrate that SPS 132 has sufficient pump capacity to incorporate the additional PDA loading for the relevant catchment. However, SPS 90 presented a flow deficiency of 11 L/s and will therefore require rectification works to achieve RCC's minimum design standards.

Further investigation identified that the SPS 90 deficiency was solely due to the downstream DN150 rising main (800 m length) being undersized, and not the power rating of the existing pumps. The DN150 pipework presented extensive headloss (in the order of 50 m) and flow velocities in excess of RCC's 3 m/s requirement. Hydraulic modelling indicated that a DN225 pipe upgrade should result in a combined pump flow velocity of 1.3 m/s and single pump flow velocity of 0.8-1.0 m/s, which is in compliance with RCC's minimum and maximum flow velocity requirements respectively. The pipe upgrade resulted in the friction headloss to significantly decrease to approximately 12 m along the length of the rising main, allowing the pumps to operate above the required PWWF of 53.2 L/s.

The proposed pipe upgrade did however result in the model to show the existing pumps operating at approximately 75-80 L/s combined flow, which resulted in the downstream gravity network to present capacity deficiencies. It is therefore recommended that the SPS 90 pump set is renewed and adjusted, in conjunction with the DN225 pipe upgrade, to achieve a combined pump flow rate that operates closer to the catchment's estimated PWWF (53 L/s). This flow rate resulted in the model to show sufficient capacity in the downstream gravity network, i.e. flow depths remained within pipe obvert. These works should also include renewal of the wet well (e.g. epoxy coating) and internal pipework.

Refer to Appendix 3 for dynamic pump modellings results.

3.2 Wet Wells

An assessment on the operational storage capacity of the SPS 132 and SPS 90 wet wells was undertaken, as per the methodology described in Section 2.2 of this report. Table 3-2 below shows a summary of results and Appendix 4 presents detailed calculations.

Table 3-2. Operational storage capacity assessment results (post-development)

| SPS | 2041 Op. Storage Capacity Available | 2041 Op. Storage Capacity Required |
|---------|-------------------------------------|------------------------------------|
| SPS 90 | 1.7 kL | 3.2 kL |
| SPS 132 | 4.3 kL | 1.7 kL |

The results in the above table demonstrate that there is sufficient operational storage capacity at SPS 132, to incorporate the PDA's ultimate sewage loading, however SPS 90 presented a 1.5 kL deficiency. Further modelling identified that adjustments to the SPS 90 duty pump start/stop levels could increase the available operational storage to 3.6 kL, avoiding the need for a well upgrade. This was based on a duty start level 50 mm below the invert of the discharging gravity line and a duty stop level 400 mm above the invert of the well floor. It is therefore recommended that the SPS 90 duty start and stop levels are adjusted to RL -3.2 m and RL -4.4 m to achieve RCC's minimum operational volume standard and avoid an upgrade to the well.

As previously discussed, it is recommended that the SPS 90 well (and internal pipework) is renewed, at the time of the proposed pump renewal/adjustment.

Refer to Appendix 4 for detailed modelling calculations.

3.3 Gravity Mains

As per the methodology described in Section 2.2 of this report, gravity pipe flow depths were assessed against RCC's minimum requirements, from site connection to each of the relevant pump stations. The analysis identified that SPS 132 gravity network should have sufficient capacity to incorporate the PDA's additional loading without the need for pipe upgrades. For SPS 90 however, there were significant deficiencies identified for pipework directly upstream of the pump station and along Outridge Street. The following upgrades were required to resolve within RCC's design standards.

- 154 m x DN150 duplication gravity main along Banana Street
- 172 m x DN200 duplication gravity main along Banana Street
- 66 m x DN225 duplication gravity main along Outridge Street

To determine the impact of the SPS 90 flow capacity increase identified in Section 3.1 of this report, downstream gravity mains were assessed up to SPS 67. This analysis identified no deficiencies with the combined flow increase to 53 L/s, avoiding the need for additional pipe upgrades.

Refer to Appendix 5 for detailed modelling results and gravity main profiles.

3.4 Emergency Storage

An emergency storage capacity assessment was undertaken on the SPS 132 and SPS 90 catchments, as per the methodology described in Section 2.2 of this report. Based on an overflow level of RL 1.47 m for SPS 132 and 1.01 m for SPS 90 (considering design standard of 300 mm below surface level), the analysis identified the following overflow time durations.

Table 3-3. Emergency storage ADWF retention time results

| SPS | 2041 ES Capacity Available (pre-develop.) | 2041 ES Capacity Available (post-develop.) |
|---------|---|--|
| SPS 90 | 6H 0M | 2H 56M |
| SPS 132 | 11H 2M | 9H 15M |

The above table shows that SPS 132 has sufficient emergency storage capacity to incorporate the Weinam Creek PDA loading, however SPS 90 presented a 1 hour deficiency (approximately). Based on an ADWF of 10.6 L/s, SPS 90 will require an additional 41 kL storage to satisfy RCC's design requirement of 4 hours ADWF. The installation of a 41 kL offline storage tank is therefore recommended to incorporate the additional Weinam Creek PDA loading. The pump station is located

within the Neville Stafford Park and a desktop review indicates there's sufficient space for the offline tank, adjacent to the existing well.

Refer to Appendix 6 for modelling results pre- and post-development

3.5 Sewer Infrastructure Upgrades

As previously discussed, the following infrastructure upgrades are required to incorporate the additional loading from the Weinam Creek PDA, within the SPS 90 catchment. Note the hydraulic analysis identified that the SPS 132 catchment does not require any infrastructure upgrades.

- Renew the wet well, including epoxy coating of the walls, replacement of internal pipework and adjustment/renewal of existing pumps to 53 L/s combined flow (in conjunction with rising main upgrade – refer below).
- Upgrade rising main from DN150 to DN225 (800m)
- Duplication gravity main along Banana Street and Outridge Street DN150, DN200 and DN225 (392 m)
- Install 41 kL offline emergency storage tank adjacent to existing SPS 90 well.

Refer to Appendix 7 for a layout plan of the proposed upgrades and the table below for associated capital cost estimates. Appendix 8 has detailed costing and assumptions.

Table 3-4. Summary of the capital cost estimate for sewer upgrades

| Catchment | Proposed Infrastructure | \$ / Unit Rate | Capital Cost (\$) | Purpose |
|--------------|---|-------------------------------------|-------------------|--|
| SPS 90 | 800 m x DN2225 pressure main | \$440 / m | \$352k | Comply SEQ Code flow velocity and increase pump capacity |
| | Duty/assist pump renewal/adjustment | \$500 / kw + install \$5k | \$25k | Reduce flow to downstream catchment |
| | Well and internal pipework renewal | Nil | \$500k | Extend asset life and reduce risk of failure |
| | 41 kL offline ES tank | \$4,389 / kL | \$180k | Comply SEQ Code 4 hours ADWF retention |
| | 154 m x DN150 GM 172 m x DN200 GM 66 m x DN225 GM | \$594 / m \$726 / m \$796 / m | \$269k | Comply SEQ Code flow depth |
| TOTAL | | | \$1.326M | |

Note: Refer Appendix 8 for assumptions and calculation details.

3.6 Timing of Construction

The timing of construction is recommended as two separate works packages (details below). This is to achieve required network capacities and/or provide a more economical outcome from related works being undertaken simultaneously. Estimated trigger points for each of these packages are as follows.

- Package 1, DN150/DN200/DN225 duplication gravity main required at approximately 500 EP growth upstream of Banana Street. It is estimated this package of works will be required between 2023 to 2025.
- Package 2, DN225 rising main upgrade, pump renewal, wet well renewal and offline emergency storage tank. This would be required at approximately 1,800 EP growth within the catchment, including population growth outside of the Weinam Creek PDA. It is estimated this packages of works will be required between 2025 to 2027.

It is recommended the above work packages are installed with close monitoring of development and population growth within the SPS 90 catchment and Weinam Creek PDA.

4 CONCLUSION

The Weinam Creek Priority Development Area (PDA) is located in Redland Bay, on the Moreton Bay foreshore, within the Redland City Council (RCC) Local Government Area (LGA). The Economic Development Queensland (EDQ) Weinam Creek PDA Development Scheme has proposed a mixed-use master plan, majority of which will be high density residential apartment living, with buildings up to 7 storeys in height. The ultimate population density for the development scheme has been estimated at 3,000 Equivalent Population (EP) by Redland Investment Corporation (RIC).

EDQ's Weinam Creek PDA planning density (3,000 EP) far exceeds that of RCC's Local Government Infrastructure Plan (LGIP) ultimate planning demands (approximately 1,096 EP). A detailed sewerage planning study was therefore undertaken to determine the impact that the additional loading will have on the existing network, and to identify infrastructure upgrades necessary to achieve RCC's minimum design standards.

The hydraulic analysis identified that there is sufficient capacity within the SPS 132 catchment, to incorporate the additional Weinam Creek PDA loading, up to the 2041 planning horizon. For the SPS 90 catchment however, insufficient capacity was identified at both the existing (2017/18) and 2041 planning horizon. A summary of the deficiencies and proposed upgrades to resolve are as follows.

- Insufficient gravity main flow depth capacity was identified along Outride Street and Banana Street across all planning horizons. A 390 m, DN150, DN200 and DN225 duplication main is therefore required to satisfy RCC's relevant Design Standards (d/D flow depth @ 75% for proposed pipework).
- Insufficient pump flow capacity was identified at SPS 90 across all planning horizons. This was identified to be a rising main capacity issue, as opposed to a pump capacity issues. Therefore, an 800 m, DN225 pipe upgrade is required to satisfy RCC's relevant Design Standard (3 m/s maximum flow velocity). To limit the impact on the downstream catchment, a renewal of the existing pumps and wet well will also be required.
- Insufficient emergency storage capacity was identified for the SPS 90 catchment, across all planning horizons. A 41 kL storage upgrade is therefore required to satisfy RCC's relevant Design Standard (4 hours ADWF storage).

A capital cost estimate for the installation of the proposed sewer infrastructure upgrades is as follows.

| Catchment | Proposed Infrastructure | \$ / Unit Rate | Capital Cost (\$) | Purpose |
|--------------|---|-------------------------------------|-------------------|--|
| SPS 90 | 800 m x DN2225 pressure main | \$440 / m | \$352k | Comply SEQ Code flow velocity and increase pump capacity |
| | Duty/assist pump renewal/adjustment | \$500 / kw + install \$5k | \$25k | Reduce flow to downstream catchment |
| | Well and internal pipework renewal | Nil | \$500k | Extend asset life and reduce risk of failure |
| | 41 kL offline ES tank | \$4,389 / kL | \$180k | Comply SEQ Code 4 hours ADWF retention |
| | 154 m x DN150 GM 172 m x DN200 GM 66 m x DN225 GM | \$594 / m \$726 / m \$796 / m | \$269k | Comply SEQ Code flow depth |
| TOTAL | | | \$1.326M | |

The approximate timing of construction for these items is as follows.

- Package 1, DN150/DN200/DN225 duplication gravity main required at approximately 500 EP growth upstream of Banana Street. It is estimated this package of works will be required between 2023 to 2025.
- Package 2, DN225 rising main upgrade, pump renewal, wet well renewal and offline emergency storage tank required at approximately 1,800 EP growth within the catchment, including population increase outside of the Weinam Creek PDA. It is estimated this packages of works will be required between 2025 to 2027.

It is recommended the proposed augmentation works is undertaken prior to the identified EP trigger points above, in addition to completing the following tasks.

- Validation of the modelling outcomes presented in this report against, field surveys, historical records, SCADA data etc. during the detailed design phase of works.
- Undertake discussions with RCC's IC Unit regarding the implementation of the proposed upgrades including apportionment of headworks charges to this area.

5 APPENDICES


Appendix 1. Weinam Creek PDA Master Plan




weinam creek

master plan

Ref. No. 133693 Date : March 2019 Scale 1 : 1500@A1




Appendix 2. Sewerage catchments servicing the Weinam Creek PDA






Legend

| | | | | | | | |
|------------------------|------------------|--------------------------|----------------|-----------|------------------------------|--|---------------|
| | Current Land | WW Pressure Pipes | | Operating | WW Non-pressure Pipes | | Trunk Gravity |
| | Weimam Creek PDA | | Out of Service | | Reticulation | | |
| | WW Catchment | | Decommissioned | | Effluent Outflow | | |
| WW Pumpstations | | | | | Effluent Reuse | | |
| | Operating | | | | | | |


| | | | | |
|--|------------|--|------|------|
| D1 | 17/02/2020 | JM | MI | MI |
| Issue | Date | By | Chkd | Appd |
| <p>Disclaimer: © Redland City Council, Queensland 2019 or © State of Queensland 2019.</p> <p>No Warranty given in relation to the data (including accuracy, reliability, completeness, currency or suitability) and no liability accepted (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data. Data must not be used for direct marketing or be used in breach of privacy laws.</p> | | | | |
|  | | Redland Water PO Box 21 Cleveland QLD 4163 | | |
| Job Title Weinam Creek PDA | | | | |
| Drawing Title Sewer catchments servicing PDA | | | | |
| Scale at A3 1:406,300 | | Drawing Status Draft V1 | | |
| Coordinate System GDA 1994 MGA Zone 56 | | | | |
| Date of Print 17/02/2020 | | Drawing No 001 | | |



Appendix 3. Pump station modelling results for Weinam PDA








SPS 132, 2041 Post-develop.








SPS 90, 2041 Pre-develop.








SPS 90, 2041 Post-develop.









Appendix 4. Wet well modelling results for Weinam Creek PDA

| | | 2041 Post-develop. | |
|--|---------------------|--------------------|-------------|
| | | SPS 90 | SPS 132 |
| Single Pump Capacity Required | Catchment EP | 4,377.0 | 2,055.0 |
| | Pump Arrangement | Duty/Assist | Duty/Assist |
| | C1 | 4.0 | 4.5 |
| | ADWF (L/s) | 10.6 | 5.0 |
| | Q (L/s) | 42.2 | 22.3 |
| Operational Storage Capacity Required | Duty Flow (L/s) | 42.2 | 22.3 |
| | Duty Head (m) | - | - |
| | Pump Efficiency (%) | - | - |
| | Duty Power (kW) | <100 | <100 |
| | No. pump starts (n) | 12.0 | 12.0 |
| | OSCR (kL) | 3.2 | 1.7 |
| Operational Storage Capacity Available | Duty Start (m) | -3.2 | -3.2 |
| | Duty Stop (m) | -4.4 | -3.7 |
| | Duty Height (m) | 1.16 | 0.5 |
| | WW Diam. (m) | 2.0 | 3.3 |
| | OSCA (kL) | 3.6 | 4.3 |
| OUTCOME | Difference (kL) | +0.5 | +2.6 |
| | Pass / Fail | PASS | PASS |

Note: Above calculations include the proposed duty start/stop level changes for SPS 90, i.e. duty start at 50 mm below invert of gravity main and duty stop at 400 mm above WW IL.

Appendix 5. Gravity main modelling results for Weinam Creek PDA

| SPS 132 - 2041 PWWF Pre-develop. | | | | | | |
|----------------------------------|------------|------------------|----------------------|---------------------|----------------|---------|
| Name | Diam. (mm) | Link Water Level | Link Discharge (L/s) | Link Velocity (m/s) | Link Depth (m) | d/D (%) |
| 56683 | 214 | -2.676 | 1.629 | 0.347 | 0.034 | 15.7% |
| 56684 | 214 | -2.616 | 1.629 | 0.413 | 0.034 | 15.7% |
| 56685 | 214 | -2.356 | 1.629 | 0.413 | 0.034 | 15.7% |
| 56686 | 214 | -2.099 | 1.586 | 0.332 | 0.041 | 19.2% |
| 56687 | 214 | -1.862 | 1.169 | 0.403 | 0.028 | 13.3% |
| 56688 | 214 | -1.503 | 1.072 | 0.379 | 0.027 | 12.7% |
| 56689 | 150 | -1.171 | 0.563 | 0.448 | 0.019 | 12.4% |
| 56690 | 150 | -0.144 | 0.387 | 0.401 | 0.016 | 10.3% |
| 56691 | 150 | -1.207 | 0.308 | 0.223 | 0.023 | 15.5% |
| 56692 | 150 | -0.887 | 0.194 | 0.271 | 0.013 | 8.4% |
| 56693 | 150 | -0.584 | 0.050 | 0.209 | 0.006 | 4.0% |
| 56694 | 150 | -0.095 | 0.044 | 0.241 | 0.005 | 3.4% |
| 56695 | 150 | -0.602 | 0.087 | 0.260 | 0.008 | 5.0% |
| 56696 | 150 | 0.058 | 0.087 | 0.224 | 0.008 | 5.5% |
| Inlet_132_1_5 6682 | 233 | -3.205 | 1.580 | 0.037 | 1.295 | 555.9% |

| SPS 132 - 2041 PWWF Post-develop. | | | | | | |
|-----------------------------------|------------|------------------|----------------------|---------------------|----------------|---------|
| Name | Diam. (mm) | Link Water Level | Link Discharge (L/s) | Link Velocity (m/s) | Link Depth (m) | d/D (%) |
| 56683 | 214 | -2.648 | 5.534 | 0.510 | 0.062 | 28.9% |
| 56684 | 214 | -2.576 | 5.534 | 0.517 | 0.074 | 34.4% |
| 56685 | 214 | -2.322 | 5.534 | 0.548 | 0.068 | 32.0% |
| 56686 | 214 | -2.054 | 4.796 | 0.392 | 0.086 | 40.4% |
| 56687 | 214 | -1.826 | 2.938 | 0.398 | 0.064 | 30.0% |
| 56688 | 214 | -1.487 | 2.599 | 0.484 | 0.043 | 20.1% |
| 56689 | 150 | -1.170 | 0.678 | 0.474 | 0.020 | 13.5% |
| 56690 | 150 | -0.145 | 0.339 | 0.385 | 0.015 | 9.7% |
| 56691 | 150 | -1.183 | 1.243 | 0.330 | 0.047 | 31.4% |
| 56692 | 150 | -0.874 | 0.904 | 0.430 | 0.026 | 17.7% |
| 56693 | 150 | -0.573 | 0.452 | 0.407 | 0.017 | 11.4% |
| 56694 | 150 | -0.087 | 0.339 | 0.445 | 0.013 | 8.8% |
| 56695 | 150 | -0.592 | 0.226 | 0.248 | 0.018 | 12.0% |
| 56696 | 150 | 0.063 | 0.226 | 0.299 | 0.013 | 8.7% |
| Inlet_132_1_5 6682 | 233 | -2.809 | 5.534 | 0.601 | 0.061 | 26.0% |

| SPS 90 - 2041 PWWF Pre-develop. | | | | | | |
|---------------------------------|------------|------------------|----------------------|---------------------|----------------|---------|
| Name | Diam. (mm) | Link Water Level | Link Discharge (L/s) | Link Velocity (m/s) | Link Depth (m) | d/D (%) |
| 232863 | 150 | 4.078 | 0.488 | 0.164 | 0.048 | 31.9% |
| 29531 | 214 | -0.291 | 15.709 | 0.701 | 0.129 | 60.5% |
| 29570 | 150 | 5.716 | 1.363 | 0.651 | 0.026 | 17.6% |
| 29571 | 150 | 4.187 | 1.469 | 1.381 | 0.017 | 11.0% |
| 29572 | 150 | 4.078 | 0.041 | 0.019 | 0.048 | 31.9% |
| 29573 | 150 | 3.749 | 1.999 | 0.549 | 0.039 | 26.0% |
| 29574 | 150 | 0.779 | 2.015 | 0.973 | 0.029 | 19.4% |
| 29575 | 150 | 0.563 | 2.064 | 0.513 | 0.043 | 28.4% |

| | | | | | | |
|---------------------|-----|--------|--------|-------|-------|--------|
| 29576 | 150 | 0.253 | 2.116 | 0.757 | 0.033 | 22.2% |
| 29577 | 150 | 0.563 | 0.032 | 0.088 | 0.013 | 8.4% |
| 29578 | 150 | -0.625 | 2.118 | 0.593 | 0.045 | 30.1% |
| 29579 | 150 | -1.085 | 2.427 | 0.543 | 0.045 | 29.9% |
| 29580 | 150 | -0.625 | 0.299 | 0.328 | 0.015 | 10.1% |
| 29581 | 150 | 7.091 | 1.238 | 0.809 | 0.021 | 14.2% |
| 29582 | 150 | 7.930 | 0.207 | 0.383 | 0.010 | 7.0% |
| 29583 | 150 | 8.137 | 0.083 | 0.277 | 0.007 | 4.6% |
| 29584 | 150 | 6.379 | 0.156 | 0.367 | 0.009 | 5.9% |
| 29585 | 150 | 5.471 | 0.284 | 0.486 | 0.011 | 7.3% |
| 29586 | 150 | 4.826 | 0.416 | 0.404 | 0.016 | 10.8% |
| 29587 | 150 | 4.920 | 0.219 | 0.410 | 0.010 | 6.9% |
| 29588 | 150 | 5.268 | 0.157 | 0.421 | 0.008 | 5.4% |
| 29589 | 150 | 4.009 | 0.647 | 0.503 | 0.019 | 12.6% |
| 29590 | 150 | 2.094 | 0.659 | 0.759 | 0.014 | 9.6% |
| 29591 | 150 | 1.801 | 0.659 | 0.443 | 0.021 | 13.9% |
| 29592 | 219 | -0.542 | 16.010 | 0.727 | 0.148 | 67.7% |
| 29593 | 214 | -0.810 | 20.942 | 0.670 | 0.180 | 84.0% |
| 29594 | 150 | 0.850 | 0.138 | 0.254 | 0.010 | 7.0% |
| 29595 | 150 | 1.015 | 0.041 | 0.204 | 0.005 | 3.6% |
| 29596 | 150 | 1.155 | 0.043 | 0.211 | 0.005 | 3.6% |
| 29597 | 150 | -1.685 | 2.881 | 0.530 | 0.055 | 36.8% |
| 29598 | 150 | 1.127 | 0.101 | 0.311 | 0.007 | 4.9% |
| 29599 | 150 | 1.537 | 0.064 | 0.229 | 0.007 | 4.5% |
| 29600 | 150 | -1.855 | 3.726 | 0.524 | 0.055 | 37.0% |
| 29601 | 150 | -2.081 | 4.000 | 0.572 | 0.059 | 39.1% |
| 29602 | 150 | 0.106 | 0.051 | 0.205 | 0.006 | 4.1% |
| 29603 | 150 | 1.036 | 0.051 | 0.199 | 0.006 | 4.2% |
| 29604 | 219 | -1.261 | 21.650 | 0.805 | 0.149 | 68.0% |
| 29605 | 150 | 0.064 | 0.032 | 0.257 | 0.004 | 2.6% |
| 29606 | 219 | -1.628 | 21.682 | 0.911 | 0.122 | 55.6% |
| 29611 | 214 | -1.968 | 23.140 | 0.834 | 0.152 | 71.1% |
| 29612 | 214 | -2.203 | 23.264 | 1.007 | 0.127 | 59.3% |
| 29614 | 150 | -2.185 | 4.000 | 0.563 | 0.065 | 43.0% |
| 29615 | 150 | -2.523 | 4.598 | 0.489 | 0.087 | 58.3% |
| 29616 | 150 | 0.860 | 0.634 | 0.458 | 0.020 | 13.2% |
| 29617 | 150 | 1.454 | 0.027 | 0.208 | 0.004 | 2.6% |
| 29618 | 150 | -2.761 | 5.480 | 0.514 | 0.099 | 66.1% |
| 29619 | 150 | -2.870 | 5.677 | 0.463 | 0.110 | 73.1% |
| Inlet_090_296 13 | 214 | -3.712 | 29.823 | 0.749 | 1.078 | 503.5% |

SPS 90 - 2041 PWWF Post-develop. + DN150/200/225 Duplication Main


| Name | Diam. (mm) | Link Water Level | Link Discharge (L/s) | Link Velocity (m/s) | Link Depth (m) | d/D (%) |
|--------|------------|------------------|----------------------|---------------------|----------------|---------|
| 232863 | 150 | 4.2 | 2.7 | 0.2 | 0.131 | 87.3% |
| 29531 | 214 | -0.3 | 15.7 | 0.7 | 0.138 | 64.7% |
| 29570 | 150 | 5.7 | 3.2 | 0.8 | 0.041 | 27.0% |
| 29571 | 150 | 4.2 | 4.0 | 1.9 | 0.027 | 17.9% |
| 29572 | 150 | 4.2 | 1.0 | 0.1 | 0.131 | 87.3% |
| 29573 | 150 | 3.8 | 7.6 | 0.8 | 0.079 | 52.9% |
| 29574 | 150 | 0.8 | 7.8 | 0.9 | 0.097 | 64.9% |

| | | | | | | |
|---------------------|-----|------|------|-----|-------|--------|
| 29575 | 150 | 0.6 | 8.4 | 0.6 | 0.118 | 78.6% |
| 29576 | 150 | 0.3 | 8.9 | 0.8 | 0.112 | 74.5% |
| 29577 | 150 | 0.6 | 0.2 | 0.0 | 0.088 | 58.6% |
| 29578 | 150 | -0.6 | 9.7 | 0.9 | 0.105 | 70.1% |
| 29579 | 150 | -1.0 | 7.0 | 0.6 | 0.106 | 70.9% |
| 29580 | 150 | -0.6 | 3.7 | 0.5 | 0.075 | 50.1% |
| 29581 | 150 | 7.1 | 1.5 | 0.9 | 0.023 | 15.6% |
| 29582 | 150 | 7.9 | 0.9 | 0.6 | 0.022 | 14.4% |
| 29583 | 150 | 8.2 | 0.4 | 0.3 | 0.023 | 15.4% |
| 29584 | 150 | 6.4 | 0.8 | 0.6 | 0.019 | 12.5% |
| 29585 | 150 | 5.5 | 1.3 | 0.8 | 0.023 | 15.3% |
| 29586 | 150 | 4.8 | 1.3 | 0.6 | 0.028 | 18.9% |
| 29587 | 150 | 4.9 | 0.8 | 0.6 | 0.019 | 12.5% |
| 29588 | 150 | 5.3 | 0.6 | 0.6 | 0.015 | 10.0% |
| 29589 | 150 | 4.0 | 2.3 | 0.7 | 0.035 | 23.3% |
| 29590 | 150 | 2.1 | 2.5 | 0.8 | 0.040 | 26.5% |
| 29591 | 150 | 1.8 | 2.5 | 0.7 | 0.040 | 26.6% |
| 29592 | 219 | -0.4 | 17.9 | 0.5 | 0.271 | 123.7% |
| 29593 | 214 | -0.7 | 22.8 | 0.6 | 0.303 | 141.7% |
| 29594 | 150 | 0.9 | 2.2 | 0.6 | 0.040 | 26.8% |
| 29595 | 150 | 1.1 | 0.4 | 0.1 | 0.050 | 33.5% |
| 29596 | 150 | 1.2 | 0.9 | 0.5 | 0.023 | 15.1% |
| 29597 | 150 | -1.6 | 8.6 | 0.7 | 0.107 | 71.5% |
| 29598 | 150 | 1.1 | 1.3 | 0.7 | 0.025 | 16.8% |
| 29599 | 150 | 1.5 | 0.4 | 0.4 | 0.017 | 11.1% |
| 29600 | 150 | -1.8 | 8.1 | 0.7 | 0.082 | 54.7% |
| 29601 | 150 | -2.0 | 8.3 | 0.6 | 0.109 | 72.7% |
| 29602 | 150 | 0.1 | 2.3 | 0.6 | 0.039 | 25.7% |
| 29603 | 150 | 1.1 | 2.3 | 0.6 | 0.039 | 26.2% |
| 29604 | 219 | -1.1 | 26.6 | 0.7 | 0.327 | 149.5% |
| 29605 | 150 | 0.1 | 2.0 | 0.9 | 0.027 | 18.3% |
| 29606 | 219 | -1.5 | 28.6 | 0.8 | 0.285 | 130.0% |
| 29611 | 214 | -1.9 | 31.5 | 0.9 | 0.204 | 95.4% |
| 29612 | 214 | -2.2 | 31.6 | 1.1 | 0.148 | 69.1% |
| 29614 | 150 | -2.1 | 8.8 | 0.7 | 0.110 | 73.4% |
| 29615 | 150 | -2.5 | 9.1 | 0.6 | 0.133 | 88.6% |
| 29616 | 150 | 0.9 | 1.2 | 0.6 | 0.028 | 18.3% |
| 29617 | 150 | 1.5 | 0.0 | 0.0 | 0.005 | 3.3% |
| 29618 | 150 | -2.6 | 8.7 | 0.5 | 0.229 | 153.0% |
| 29619 | 150 | -2.7 | 5.7 | 0.3 | 0.306 | 204.2% |
| Inlet_090_296 13 | 214 | -3.0 | 54.0 | 1.6 | 0.173 | 81.0% |
| Link_12 | 150 | -1.0 | 6.7 | 0.6 | 0.106 | 70.9% |
| Link_13 | 150 | -1.6 | 8.4 | 0.7 | 0.107 | 71.5% |
| Link_15 | 200 | -1.8 | 11.3 | 0.7 | 0.090 | 44.9% |
| Link_16 | 200 | -2.0 | 11.4 | 0.7 | 0.109 | 54.5% |
| Link_17 | 200 | -2.1 | 11.3 | 0.7 | 0.110 | 55.1% |
| Link_18 | 200 | -2.5 | 11.7 | 0.6 | 0.133 | 66.5% |
| Link_19 | 225 | -2.6 | 13.7 | 0.4 | 0.229 | 102.0% |
| Link_20 | 225 | -2.7 | 16.7 | 0.4 | 0.306 | 136.1% |


Note: Link_19 and Link_20 show results that do not comply with SEQ Code 75% d/D flow depth, however this is due to erroneous results from Mike Urban, as the well HGL was above the invert level of this pipework, which could not be


altered. Manual calculations showed that the DN150/DN225 duplication main should be sufficient to achieve 75% d/D. Further modelling will be required at the detailed design stage to confirm pipe sizing.

SPS 90 Gravity Mains, 2041 Pre-develop.




SPS 90 Gravity Mains, 2041 Post-develop.







| SPS 67 - 2041 PWWF Post-develop. + SPS 90 DN225 Rising Main Upgrade | | | | | | |
|---|------------|------------------|----------------------|---------------------|----------------|---------|
| Name | Diam. (mm) | Link Water Level | Link Discharge (L/s) | Link Velocity (m/s) | Link Depth (m) | d/D (%) |
| 28781 | 629 | -2.679 | 235.647 | 0.968 | 0.501 | 79.6% |
| 29121 | 600 | 2.394 | 209.356 | 0.945 | 0.534 | 89.0% |
| 29122 | 600 | 2.066 | 209.288 | 1.048 | 0.386 | 64.4% |
| 29123 | 600 | 1.227 | 209.288 | 1.086 | 0.447 | 74.4% |
| 29124 | 600 | 0.373 | 239.074 | 1.210 | 0.543 | 90.4% |
| 29125 | 600 | 0.205 | 238.220 | 0.889 | 0.535 | 89.2% |
| 29126 | 600 | -0.007 | 237.089 | 0.924 | 0.503 | 83.9% |
| 29127 | 600 | -0.428 | 235.972 | 1.156 | 0.382 | 63.7% |
| 29128 | 600 | -2.475 | 235.745 | 1.389 | 0.455 | 75.8% |
| 29132 | 600 | 4.553 | 204.350 | 0.820 | 0.493 | 82.1% |
| 29134 | 600 | 4.412 | 204.791 | 0.830 | 0.492 | 82.0% |
| 29135 | 600 | 4.196 | 204.655 | 0.761 | 0.546 | 91.0% |
| 29136 | 600 | 4.117 | 208.168 | 0.791 | 0.557 | 92.8% |
| 29137 | 600 | 3.919 | 208.745 | 0.856 | 0.479 | 79.8% |
| 29195 | 600 | 3.673 | 209.430 | 1.001 | 0.403 | 67.2% |
| 29380 | 600 | 5.116 | 190.257 | 0.850 | 0.436 | 72.7% |
| 29381 | 270 | 7.391 | 58.204 | 1.431 | 0.181 | 66.9% |
| 29384 | 270 | 7.622 | 56.306 | 0.983 | 0.282 | 104.5% |
| 29388 | 270 | 7.996 | 56.216 | 0.981 | 0.256 | 94.8% |
| 29391 | 270 | 8.477 | 56.216 | 0.981 | 0.427 | 158.3% |
| 29392 | 270 | 9.338 | 55.265 | 1.063 | 0.268 | 99.1% |
| 29393 | 600 | 5.005 | 190.259 | 0.860 | 0.435 | 72.6% |
| 29399 | 600 | 4.919 | 190.888 | 0.851 | 0.449 | 74.8% |
| 29401 | 600 | 4.706 | 191.168 | 0.856 | 0.436 | 72.7% |
| 29472 | 270 | 10.368 | 54.578 | 1.049 | 0.248 | 91.7% |
| Inlet_067_287 84 | 629 | -2.937 | 242.658 | 1.513 | 0.313 | 49.7% |




Appendix 6. Emergency storage modelling results for Weinam Creek PDA




SPS 132, 2041 Post-develop. (9H 15M)




SPS 90, 2041 Pre-develop. (6H 0M)





Appendix 7. Proposed sewer infrastructure upgrades for the Weinam Creek PDA



Legend

Current Land

Weimam Creek PDA

WW Catchment

GM Duplication

150

200

225

RM Upgrade

225

WW Pressure Pipes

Operating

Out of Service

Decommissioned


WW Non-pressure Pipes

Trunk Gravity

Reticulation

Effluent Outflow

Effluent Reuse

| | | | | |
|--|-----------|--|------|------|
| D1 | 3/04/2020 | JM | MI | MI |
| Issue | Date | By | Chkd | Appd |
| <p>Disclaimer: © Redland City Council, Queensland 2019 or © State of Queensland 2019.</p> <p>No Warranty given in relation to the data (including accuracy, reliability, completeness, currency or suitability) and no liability accepted (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data. Data must not be used for direct marketing or be used in breach of privacy laws.</p> | | | | |
|  | | Redland Water PO Box 21 Cleveland QLD 4163 | | |
| Job Title Weinam Creek PDA | | | | |
| Drawing Title Sewer catchments servicing PDA | | | | |
| Scale at A3 1:406,300 | | Drawing Status Draft V1 | | |
| Coordinate System GDA 1994 MGA Zone 56 | | | | |
| Date of Print 3/04/2020 | | Drawing No 001 | | |

Appendix 8. Detailed capital cost estimate calculations and assumptions

| Catchment | Aug No. | Description | Size | Length (m) | Unit Base Rate | Adjustment Factor | Base Sub-total | Indexed Sub-total |
|--|---------|------------------------------------|-------|------------|---------------------------|-------------------|----------------|-------------------|
| SPS 90 | 1 | Rising main upgrade | DN225 | 800 | \$ 326 | 1.20 | \$312,960 | \$352,239 |
| | 2 | Duty/assist renewal | 18 kW | NA | \$500 / kW + \$7k install | NA | \$25,000 | \$25,000 |
| | 3 | Well and internal pipework renewal | NA | NA | NA | NA | \$500,000 | \$500,000 |
| | 4 | Emergency storage tank | 41 kL | NA | \$ 3,676 | NA | \$150,716 | \$179,963 |
| | 5 | Gravity mains | DN150 | 154 | \$ 385 | 1.37 | \$81,227 | \$ 91,422 |
| | 6 | | DN200 | 172 | \$ 471 | 1.37 | \$110,986 | \$124,916 |
| | 7 | | DN225 | 66 | \$ 516 | 1.37 | \$46,657 | \$52,513 |
| Note 1: Assumed soft rock urban for all pipework | | | | | | | TOTAL | \$1,326,053 |

Note 1: Assumed soft rock urban for all pipework

Note 2: Aug No. 2 was estimated based on RCC costs from recent works

Note 3: Aug No. 3 was a high level estimation based on RCC historical works

Note 4: Emergency storage tank cost estimation sourced from Cardno's CoGC 2014 wet well unit rates, indexed at 3% per annum for 6 years

Note 5: Gravity main cost estimation sourced from Cardno's RCC 2017 unit rates, indexed at 3% per annum for 4 years

Note 6: Rates include 20% overheads. No contingency adjustments have been applied.