

67 to 69 Shore St East Cleveland QLD 4163

Water Supply and Sewerage Network Capacity Assessment

FINAL Report V1 - 21 June, 2024



H2One Pty Ltd

Water, Sewer and Stormwater Engineering Specialists

H2One Pty Ltd
ABN 20 130 354 764

P 07 5463 9538
E info@H2One.com.au
W h2one.com.au

Reviewed by RPEQ	Reg. No.	Signed	Date
Joshua May	18064		21 June, 2024

Version	Date	Author	Reviewer
DRAFT - V1	21 June, 2024	D Colledge	J May
FINAL - V1	21 June, 2024	D Colledge	J May

Copyright in the whole and every part of this document belongs to H2One Pty Ltd and may not be used, sold, transferred, copied or reproduced in whole or in part in any manner or form or in or on any media to any person without the prior written approval of H2One Pty Ltd.

TABLE OF CONTENTS

1	INTRODUCTION.....	2
1.1	Background	2
1.2	Objectives.....	2
1.3	Sewer Catchment System	2
1.4	Water Supply Zone	2
1.5	Demand Assessment	3
2	METHODOLOGY	4
2.1	Desired Standards of Service	4
2.2	Sewerage Network Assessment.....	5
2.3	Water Supply Network Assessment.....	5
3	RESULTS	7
3.1	Sewerage Network Assessment.....	7
3.1.1	Pumps.....	7
3.1.2	Wet Wells	7
3.1.3	Gravity Mains.....	8
3.1.4	Emergency Storage	8
3.2	Water Supply Network Assessment.....	8
3.2.1	Standard Flow	8
3.2.2	Fire Flow	9
4	CONCLUSION	11
5	REFERENCE LIST	12
6	APPENDICES.....	13
	Appendix 1. Preliminary development layout plan	14
	Appendix 2. Development site and SPS 002 sewer catchment.....	15
	Appendix 3. Development site and Alexandra Hills water supply system.....	16
	Appendix 4. Pump capacity assessment results	17
	Appendix 5. Operational storage capacity assessment results	19
	Appendix 6. Gravity main capacity assessment results	20
	Appendix 7. Emergency storage capacity assessment results	22

1 INTRODUCTION

1.1 Background

A mid-rise residential tower development is currently in the planning phase of the Development Application (DA) process, located at 67 to 69 Shore Street East, Cleveland QLD 4163; Lots 12 and 13 on C14563. The land-use type and density is planned for 30 x 3+ bedroom apartments. Refer to Appendix 1 for the preliminary development layout plan.

H2One Pty Ltd was engaged to undertake a water supply and sewerage network capacity assessment to determine if the site's additional loading will impact system performance and trigger the need for infrastructure upgrades. This assessment has been prepared in accordance with Redland City Council's (RCC) minimum Design Standards; *"South East Queensland Water Supply and Sewerage Design and Construction Code"* (2020). The results of the study are presented in this report.

1.2 Objectives

The objectives of the project were as follows.

1. Assess the capacity of existing gravity mains, pressure mains, pumps, wet wells and emergency storage for the relevant sewer catchment; Sewer Pump Station (SPS) 002.
2. Assess standard flow and fire flow capacity of the relevant water supply network; Alexandra Hills Low Level Zone (LLZ).
3. Determine infrastructure upgrades necessary to achieve RCC's minimum Design Standards, where system performance failures have occurred due to the additional loadings of the new development.
4. Prepare a network capacity assessment report.

1.3 Sewer Catchment System

The development site is located within the SPS 002 sub-catchment and larger catchment area of the Cleveland Sewage Treatment Plant (STP). The proposed service connection will be located on the DN150 gravity main along Shore Street East, adjacent to the northern property boundary.

The development's sewage outfall will be conveyed west to SPS 002, via a 350 m, DN150 gravity pipe system. SPS 002 has duty-assist pumps that transfer sewage west to the downstream catchment (SPS 004), ultimately discharging to the Cleveland STP via a number of catchments.

As per RCC's 2022 Netserv model, the catchment demand is estimated at 1,295 EP and 6,094 EP, at the 2021 and Ultimate planning horizons, respectively. Refer to Appendices 1 and 2 for an overview of site location and the relevant service strategy.

1.4 Water Supply Zone

The development site is located within the Alexandra Hills LLZ, which is supplied by a series of water tanks located at the top of Alexandra Hills (RL 65 m). A network of DN600, DN500 and DN450 trunk mains distribute water east to the network surrounding the development site. The proposed service strategy is to service the development from a single connection to the existing DN100 water pipe along Shore Street East.

As per RCC's 2022 Netserv model, the Alexandra Hills LLZ currently services 98,600 EP and is projected to increase to 117,213 EP, at the Ultimate planning horizon. Refer to Appendices 1 and 3 for an overview of site location and relevant service strategy.

1.5 Demand Assessment

A water supply and sewage demand assessment was undertaken on the proposed development, to determine the approximate loading attributed to the land-use type and density. This was calculated using RCC's Equivalent Persons (EP) unit rates and average "per capita" demands for potable water and sewage; 230 L/EP/day and 210 L/EP/day, respectively. Refer to Table 1 below for a summary of the relevant demand estimate.

Table 1. Estimated water supply and sewage demands for the proposed development

Site Land-use and Density	Demand Rate	EP	Water Peak Hour Flow (L/s)	Sewage PWWF (L/s)
30 x 3 bedroom apt.	2.51 EP/Apt.	75.3	0.80	0.92

Note 1: For water demands, peak flow rates were based on the "residential" AD/PH peaking factor (4.0).

Note 2: For sewage demands, the PWWF flow rates were based on 5 x ADWF.

For the post-development scenarios, RCC's existing Netserv planning demands were removed from the hydraulic models and replaced with the demands presented in Table 1 above. The planning demands were sourced from RCC's 2022 Netserv IDM and are presented in Table 2 below.

Table 2. RCC's IDM water and sewer demands (EP) removed from the hydraulic models @ post-development

Address	Water Node ID	Sewer Node ID	2021 to Ultimate (EP)
67-69 Shore St E, Cleveland	J13223	43066	5.4

2 METHODOLOGY

2.1 Desired Standards of Service

The design standards adopted for the hydraulic assessment were based on the “*South East Queensland Water Supply and Sewerage Design and Construction Code*” (2020), with exception to the maximum depth of gravity pipe flow at 1.0 m freeboard. This requirement is merely a standard industry practice adopted by water authorities in South-east Queensland, and is not a specific design standard from either the SEQ Code or Water Service Association of Australia (WSAA) Sewerage Code.

A summary of the relevant design provisions utilised for the project is as follows.

Table 3. Design provisions adopted for the hydraulic assessment

	Provision	Specification
Sewerage	ET to EP conversion factor	2.7
	Average Dry Weather Flow (ADWF)	210 L/EP/day
	Peak Wet Weather Flow (PWWF)	5 x ADWF
	Single pump capacity	$C1 \times \text{ADWF (L/s)}$ where; $C1 = 3.5 \text{ to } 5.0$ $C1 = 15 \times (\text{EP})^{-0.1587}$
	Pump station operational storage (m^3)	$0.9 \times Q / N$ where; $Q = \text{Single pump capacity (L/s)}$ $N = \text{Number of pump starts per hour, where}$ $N = 12 \text{ for duty pump motor } < 100 \text{ kW}$ $N = 8 \text{ for duty pump motor } 100 - 200 \text{ kW}$ $N = 5 \text{ for duty pump motor } > 200 \text{ kW}$
	Pump station emergency storage (m^3)	4 hours ADWF
	Total pump station capacity (L/s)	PWWF
	Maximum depth of gravity flow (proposed system)	75% pipe diameter
	Maximum depth of gravity flow (existing system)	1.0 m below manhole level
	Maximum pressure main flow velocity	3.0 m/s
Water Supply	ET to EP conversion factor	2.7
	Average Day (AD) Demand	230 L/EP/day
	Maximum pipe velocity (m/s)	2.5 m/s
	Standard flow minimum network pressure and background demand	22m at the property boundary at PH demand
	Residential fire flow minimum network pressure and background demand	12m at 2/3 PH demand Positive pressure at PH demand Reservoir at Minimum Operating Level (15%)
	Commercial fire flow minimum network pressure and background demand	12m at PH demand
	Fire flows	Residential - 15 L/s Residential (> 3 storey) - 30 L/s Commercial/industrial - 30 L/s

2.2 Sewerage Network Assessment

The methodology adopted for the hydraulic analysis of the sewer network is as follows.

1. RCC's latest LGIP MIKE+ sewer network model was adopted for the hydraulic analysis ("Clev722P_(Netserv_Model)_v3_2023"), which incorporates the 2022 Netserv planning demands and infrastructure upgrades. For the post development scenarios, the site's total estimated sewage loading was placed onto manhole "43067", and RCC's existing Netserv demands removed from the hydraulic model as per Section 1.5 of this report.
2. The pump capacity of SPS 002 was assessed by comparing the PWWF required to service the catchment, pre- and post-development, to the available combined pump capacity presented in RCC's hydraulic model.

If the combined pump capacity was above the catchment's PWWF, relevant design standards were achieved. If it was below the PWWF, pump and pressure main upgrades were investigated until compliance was attained.

3. The operational storage of the SPS 002 wet well was subsequently evaluated by comparing the required storage capacity, post-development, against wet well volumes between the duty pump start/stop levels.

If the wet well's operational storage volume was above the minimum requirement, compliance was achieved. If it was below the minimum requirement, upgrades were investigated until design standards were achieved.

4. The flow depth of gravity mains was assessed from the proposed connection point to SPS 002, pre- and post-development. To avoid surcharging from potential deficiencies downstream, the relevant pump station was deactivated and the gravity mains discharged directly to an outlet.

If flow depths could not be maintained within RCC's specifications, pipe augmentations were investigated until Design Standards were achieved.

5. The emergency storage of the SPS 002 catchment was assessed by determining the available storage volume between the overflow level (RL 1.95 m - 0.3 m) and the duty pump start level (RL -3.07 m), including upstream gravity mains and manholes. The overflow level was sourced from the manhole with the lowest surface level ("43077"), as per RCC's hydraulic model.

The available emergency storage was compared against the 4 hour ADWF requirement. If the available storage was above the minimum requirement, compliance was achieved. If it was below the minimum requirement, compliance was not achieved and storage augmentations were investigated.

6. Modelling results were verified and findings reported.

2.3 Water Supply Network Assessment

The methodology adopted for the water supply network analysis is as follows.

1. RCC's latest MIKE+ LGIP hydraulic model was adopted for the water supply analysis ("RCC WD LGIP Model_2021 FINAL v3"). For the post-development scenarios, the site's estimated demand and diurnal patterns were placed onto node "Junction_115", and RCC's existing Netserv demands removed from the hydraulic model as per Section 1.5 of this report.
2. For all planning horizons, a 1 x Maximum Day (MD) demand standard flow hydraulic analysis was undertaken on the property connection point/s and local network, at both pre- and post-

development. Any deficiencies in the network were investigated and appropriate solutions determined.

Note: An assessment on the capacity of the water supply tanks (Alexandra Hills LLZ) was not undertaken, as the development's additional loading was considered negligible for the existing storage capacity.

3. Residential (15 L/s) and commercial (30 L/s) fire flow allocation was applied to the surrounding network as per RCC's Netserv model. For the post-development scenarios, hydrants directly servicing the subject site were allocated 30 L/s fire flow @ 2/3 PH demand, as the proposed development will exceed 3 storeys in height.
4. For all planning horizons, a fire flow hydraulic analysis was undertaken on all hydrants servicing the local network, at pre- and post-development. Any deficiencies in the network were investigated and appropriate solutions determined.
5. Modelling results were verified and findings reported.

3 RESULTS

3.1 Sewerage Network Assessment

3.1.1 Pumps

A pump capacity assessment was undertaken on SPS 002 as per the methodology described in Section 2.2 of this report. Refer to Table 4 below for a summary of results.

Table 4. Combined pump flow capacity results (post-development)

Planning Horizon	Capacity Available (L/s)	Capacity Required (L/s)	Difference (L/s)
2021	35.9	16.6	+19.3
2026	35.9	28.0	+7.9
2031	74.1	42.0	+32.1
2051	74.1	71.7	+2.4
Ultimate	74.1	74.9	-0.8

Note 1: Above figures were sourced from RCC's hydraulic model.

Note 2: RCC has a combined pump upgrade projected for the 2031 planning horizon, hence the significant increase in flow capacity from 35.9 L/s to 74.1 L/s.

The above results demonstrate that there is sufficient combined pump capacity, at SPS 002, to service the proposed development, up to the 2051 planning horizon. The Ultimate planning horizon resulted in a minor 0.8 L/s pump capacity shortfall, which can be readily rectified via RCC's LGIP pump capacity upgrade projected for the 2031 planning horizon.

However, as the minor deficiency is a projection of a 40 year+ planning horizon, it is recommended the pump capacity shortfall is disregarded and relevant development conditions are not applied to the application process.

Refer to Appendix 4 for the detailed pump modelling results.

3.1.2 Wet Wells

An assessment on the operational storage capacity of the SPS 002 wet well was undertaken with the inclusion of the development's estimated loading. Table 5 below shows a summary of results and Appendix 5 provides detailed calculations.

Table 5. Operational storage capacity results (post-development)

Planning Horizon	Storage Available (kL)	Storage Required (kL)	Difference (kL)
2021	0.47	1.19	-0.72
Ultimate	0.47	4.22	-3.75

The above table demonstrates there is insufficient operational storage capacity to incorporate the additional site loading, across all planning horizons. This result however, was determined to be a pre-existing deficiency that was not triggered by the development site, as it only accounted for 0.06 kL of the storage requirement.

Further investigation determined that the duty pump start level can be increased to the invert level of the discharging gravity main (RL -2.66 m), to provide adequate capacity up to the 2031 planning horizon. From 2036 however, a wet well storage capacity upgrade (3.75 kL) will likely be required to comply with RCC's minimum Design Standards.

Since the operation storage deficiency is a pre-existing issue, and was negligibly impacted by the development's additional loading, it is recommended the resolution of the storage capacity is undertaken by RCC, via standard LGIP processes.

3.1.3 Gravity Mains

As per the methodology described in Section 2.2, gravity main pipe flow depths were assessed against RCC's minimum requirement, from site connections to SPS 002. The analysis identified that there was sufficient capacity within the existing gravity main system to incorporate the site's loading across all planning horizons. No gravity main capacity upgrades are therefore required to service the development.

Refer to Appendix 6 for detailed modelling results and gravity main profiles.

3.1.4 Emergency Storage

An emergency storage capacity assessment was undertaken on the SPS 002 catchment, with the inclusion of the additional ADWF attributed to the proposed development. Refer to Table 6 below for a summary of outcomes and Appendix 7 for detailed calculations.

Table 6. Emergency storage capacity results (post-development)

Planning Horizon	Storage Available (kL)	Storage Required (kL)	Difference (kL)
2021	57.9	35.1	+22.8
2026	72.2	66.1	+6.1
2031	72.2	104.9	-32.7
Ultimate	72.2	190.9	-118.8

Note 1: Above figures were based on 300 mm below the overflow level (RL 1.95 m – 0.3 m) as per RCC's hydraulic model.

Note 2: RCC has a gravity main upgrade projected for the 2026 planning horizon, hence the significant increase in available storage capacity from 57.9 kL to 72.2 kL.

Note 3: Above results can be considered an estimate only as it does not consider ADWF already present within the manholes and gravity mains.

The results in Table 6 show that the SPS 002 catchment has sufficient emergency storage up to the 2026 planning horizon, with all subsequent planning horizons presenting insufficient capacity. This outcome however, was determined to be a pre-existing deficiency that was not triggered by the development site, as it only accounted for 2.45 kL of the storage requirement.

Further investigation determined that a storage capacity upgrade (118.8 kL) will likely be required, at the 2031 planning horizon, in order to comply with RCC's minimum Design Standards. However, since the emergency storage deficiency is a pre-existing issue, and the development site only had a minor contribution, it is recommended the resolution of the storage capacity is undertaken by RCC, via standard LGIP processes.

3.2 Water Supply Network Assessment

3.2.1 Standard Flow

As per the methodology described in Section 2.3 of this report, a detailed standard flow network analysis was undertaken on all planning horizons with the inclusion of the estimated development demands. A summary of results is presented below in Table 7.

Table 7. Standard flow network modelling results (pre- and post-development)

Provision	2021		Ultimate	
	Pre-develop.	Post-develop.	Pre-develop.	Post-develop.
Conn. point (Junction_115) min. pressure (m)	54.3	54.1	43.8	43.5
Network min. pressure (m)	42.5	42.4	33.0	32.9
Network min. pressure node ID	J9330		J9328	
Network no. pressure failures	0	0	0	0
Max. pipe velocity (m/s)	1.1	1.1	1.9	1.9
Network max. pipe velocity ID	9668			
Network no. velocity failures	0	0	0	0

Note 1: Peak hour was 9 am within the local network.

Note 2: Modelling with the supply reservoir at MOL was not considered, as the Capalaba Water Treatment Plant (WTP) pump station is required to operate over peak demand events.

The above results demonstrate that the network performed within RCC's Design Standards across all planning horizons. No infrastructure upgrades are therefore required to service the development for standard flow.

3.2.2 Fire Flow

As per the methodology described in Section 2.3 of this report, a detailed fire flow network analysis was undertaken on all planning horizons with the inclusion of estimated development demands. A summary of results is presented below in Table 8.

Table 8. Fire flow network modelling results (pre- and post-development)

Provision		2021		Ultimate	
		Pre-develop.	Post-develop.	Pre-develop.	Post-develop.
2/3 PH FF	Site hydrant (Junction_115) min. pressure (m) @ 15 L/s pre-develop. and 30 L/s post-develop.	48.9	29.8	40.8	22.9
	Network hydrants min. pressure (m)	22.4	22.3	16.2	16.2
	Network hydrant min. pressure node ID	J9286		J10012	
	Network hydrants no. failures	0	0	0	0
PH FF	Network hydrants min. pressure (m) @ 30 L/s	16.3	16.0	13.6	13.5
	Network hydrant min. pressure node ID	J13190		J9464	
	Network hydrants no. failures	0	0	0	0

Note 1: Within the local network, 2/3 peak hour and peak hour was 4 pm and 9 am, respectively.

Note 2: Modelling with the supply reservoir at MOL was not considered, as the Capalaba Water Treatment Plant (WTP) pump station is required to operate over peak demand events.

The above results demonstrate that the network performed within RCC's Design Standards across all planning horizons. No infrastructure upgrades are therefore required to service the development for fire flow.

4 CONCLUSION

A mid-rise residential tower development is currently in the planning phase of the Development Application (DA) process, located at 67 to 69 Shore Street East, Cleveland QLD 4163; Lots 12 and 13 on C14563. The land-use type and density is planned for 30 x 3+ bedroom apartments. Refer to Appendix 1 for the preliminary development layout plan.

H2One Pty Ltd was engaged to undertake a water supply and sewerage network capacity assessment to determine if the site's additional loading (75.3 EP) will impact system performance and trigger the need for infrastructure upgrades. The assessment was prepared in accordance with Redland City Council's (RCC) minimum Design Standards; *"South East Queensland Water Supply and Sewerage Design and Construction Code"* (2020).

The hydraulic analysis determined that, theoretically, there was sufficient capacity in the water supply and sewerage networks to incorporate the site's additional loading, across all planning horizons, without the need for infrastructure upgrades prior to development connection.

The downstream Sewer Pump Station (SPS) 002 presented minor pump, operational storage and emergency storage capacity deficiencies. However, these were determined to be either negligible, or pre-existing shortfalls that were not triggered by the development site. Refer to body of the report for more details.

In summary, it is recommended that RCC reviews the findings presented in this report and approves the relevant service connections for the development at 67 to 69 Shore Street East, Cleveland QLD.

Detailed modelling results, calculations and system plan can be observed in Appendices 1 through 7.

5 REFERENCE LIST

RCC. (2020). *SEQ Water Supply and Sewerage Design and Construction Code*. Cleveland, QLD

6 APPENDICES

Appendix 1. Preliminary development layout plan

LEGEND

- | | |
|--|--|
|  | — SITE BOUNDARY |
|  | --- EXISTING PROPERTY BOUNDARY |
|  | - - - - - EXISTING CONTOURS (AT 0.25m INTERVALS) |
|  | - - - - - EXISTING KERB |
|  | - - - - - EXISTING EDGE OF BITUMEN |
|  | - - - - - EXISTING OVERHEAD ELECTRICAL (OH) |
|  | - - - - - EXISTING GAS |
|  | - - - - - EXISTING NBN |
|  | - - - - - EXISTING STORMWATER DRAINAGE |
|  | - - - - - EXISTING SEWER |
|  | - - - - - EXISTING WATER |
|  | - - - - - DESIGN CONTOURS (AT 0.10m INTERVALS) |
|  | --- PROPOSED BUILDING OVER LINE |
|  | --- PROPOSED CHANGE OF GRADE |
|  | - - - - - PROPOSED PAVEMENT SAW CUT |
|  | - - - - - PROPOSED M1 MOUNTABLE KERB AND CHANNEL |
|  | --- PROPOSED EDGE OF BITUMEN |
|  | --- PROPOSED STORMWATER DRAINAGE |
|  | --- PROPOSED SEWER |
|  | --- PROPOSED WATER |
|  | - - - - - 90m FIRE HYDRANT COVERAGE |
|  | PROPOSED BUILDING BY OTHERS |
|  | CONCRETE PAVEMENT EXTENT |
|  | PROPOSED CONCRETE FOOTPATH |
|  | PROPOSED LANDSCAPING |
|  | PROPOSED ROAD PAVEMENT WIDENING |

FIRE HYDRANT POSITION AND
COVERAGE TO BE CONFIRMED WITH
FURTHER SURVEY DETAILING
ACCURATE HYDRANT LOCATION

PAVEMENT WIDENING TO SUIT NEW KERB AND CHANNEL AND 7m ROAD CARRIAGEWAY WIDTH. DETAILS TO BE CONFIRMED UPON RECEIPT OF FURTHER SURVEY. MINIMUM PAVEMENT RECONSTRUCTION WIDTH OF 1.2m REQUIRED.

CONSTRUCT NEW 2.5m WIDE SHARED
FOOTPATH ALONG SITE FRONTAGE

CONSTRUCT NEW M1 MOUNTABLE KERB AND CHANNEL ALONG SITE FRONTAGE TO PROVIDE 7m WIDE ROAD CARRIAGEWAY. DETAILS TO BE CONFIRMED UPON RECEIPT OF FURTHER SURVEY AND ACCURATE LOCATION OF OPPOSITE KERB AND CHANNEL. TURNOUTS TO BE PROVIDED AT EITHER END OF KERB AND CHANNEL WITH 1in10 TAPER BACK TO EXISTING EDGE OF BITUMEN.

EXISTING SEWER CONNECTION TO BE CAPPED
AT MAIN, BROKEN OUT AND REMOVED

PROVIDE NEW WATER METER AND CONNECTION TO SERVICE THE PROPOSED DEVELOPMENT. ALLOW 1.5mX0.5m SPATIAL AREA FOR WATER METER LOCATION WITHIN PROPERTY BOUNDARY AS SHOWN.

PROPOSED uPVC PROPRIETARY
STORMWATER BENDS. DETAILS
TO BE CONFIRMED.

EXISTING SEWER CONNECTION TO BE CAPPED
AT MAIN, BROKEN OUT AND REMOVED

PROVIDE NEW DN150 SEWER PROPERTY CONNECTION TO SERVICE THE DEVELOPMENT

PROPOSED LIP IN LINE GULLY
PIT IN ACCORDANCE WITH
IPWEA STD DRG No. DS-063

PROPOSED PMT TO ACHIEVE FLOOD IMMUNITY
TO 1% AEP EVENT (1% AEP EVENT IS 3.16m AHD)

PROPOSED STORMWATER TO CROSS
ABOVE EXISTING SEWER WITH MINIMUM
300mm VERTICAL CLEARANCE
APPROX. SEWER IL 1.170m

VERGE TO BE RE-GRADED AS REQUIRED TO SUIT NEW KERB AND CHANNEL AND GULLY PIT. DETAILS TO BE CONFIRMED.

SHORE STREET EAST

EXISTING DN150 AC SEWER MAIN

—SE— —SE— —SE—
EXISTING DN150 AC SEWER MAIN

EXISTING DN100 AC WATER MAIN

—SE— —SE— —SE—
EXISTING DN150 AC SEWER MAIN

ED LIP IN
CORDAM
TD DRG M

INTERNAL STORMWATER TO OUTLET TO
EXISTING 525Ø RCP WITHIN STREET.
CONSTRUCT NEW 1050Ø MANHOLE OVER
EXISTING LINE IN ACCORDANCE WITH
IPWEA STD DRG No. DS-010
APPROX. IL 1.45m

PROPOSED STORMWATER TO CROSS
ABOVE EXISTING SEWER WITH MINIMUM
300mm VERTICAL CLEARANCE
APPROX. SEWER IL 1.170m

VERGE TO BE RE-GRADED AS REQUIRED TO SUIT NEW KERB AND CHANNEL AND GULLY PIT. DETAILS TO BE CONFIRMED.


NOTES:

- | | |
|--------|--|
| NOTES: | |
| 1. | OCEANGUARDS OR SIMILAR TO BE FITTED WITHIN ALL INTERNAL FIELD INLETS |
| 2. | ALL GUTTERS AND DOWNPIPES TO BE SIZED TO CATER FOR THE 1% AEP EVENT |

NOT FOR CONSTRUCTION

[illegible]

DESIGNED	I.ERNST
DRAWN	I.ERNST
CHECKED	N.GREEN
APPROVED	



PROJECT	PROPOSED DEVELOPMENT 67 & 69 SHORE STREET EAST CLEVELAND, QLD, 4163.
DISCIPLINE	CIVIL

STATUS	PRELIMINARY ISSUE				
SHEET TITLE	CONCEPT SERVICES LAYOUT				
PROJECT NUMBER	23191	DRAWING NUMBER	23191-DWG-CV-CV-SK001	REV	B

LEGEND

- SITE BOUNDARY
EXISTING PROPERTY BOUNDARY
EXISTING CONTOURS (AT 0.25m INTERVALS)
EXISTING KERB
EXISTING EDGE OF BITUMEN
E(OH) EXISTING OVERHEAD ELECTRICAL (OH)
G EXISTING GAS
SWD EXISTING STORMWATER DRAINAGE
SE EXISTING SEWER
NBN EXISTING NBN
W EXISTING WATER
XX.XX DESIGN CONTOURS (AT 0.10m INTERVALS)
PROPOSED BUILDING OVER LINE
PROPOSED CHANGE OF GRADE
PROPOSED PAVEMENT SAW CUT
TREE PROTECTION ZONE
PROPOSED M1 MOUNTABLE KERB AND CHANNEL
PROPOSED EDGE OF BITUMEN
SWD PROPOSED STORMWATER DRAINAGE
SE PROPOSED SEWER
W PROPOSED WATER
PROPOSED RETAINING WALL
XX.XXXm X FINISHED SURFACE ELEVATION LABEL
XX.XXXm X EXISTING SURFACE ELEVATION LABEL
XX.XXXm X PROPOSED RETAINING WALL HEIGHT
X.X% PROPOSED SURFACE SLOPE

EARTHWORKS LEVELS

1. EARTHWORKS VOLUMES AND LEVELS BASED ON DRIVEWAY THICKNESS OF 150mm AND BUILDING SLAB THICKNESS OF 150mm. REFER STRUCTURAL DESIGN DRAWINGS AT DETAILED DESIGN STAGE FOR FINAL PAD THICKNESS.
2. ALL RETAINING WALL HEIGHTS ARE GIVEN FROM EXISTING SURFACE TO DESIGN (FINISHED) SURFACE.

EARTHWORKS VOLUMES


(EXISTING SURFACE TO EARTHWORKS SURFACE)	
TOTAL CUT	1015m³
TOTAL FILL	230m³
TOTAL BALANCE (CUT TO EXPORT)	785m³

CUT & FILL LEGEND

MINIMUM ELEVATION	MAXIMUM ELEVATION	COLOUR
-1.500m	-1.000m	
-1.000m	-0.500m	
-0.500m	0.000m	
0.000m	0.500m	
0.500m	1.000m	
1.000m	1.500m	

B	FOR APPROVAL	JB	NG	01.02.24
A	PRELIMINARY ISSUE	IE	NG	19.01.24
REV	REVISION DETAILS	DRWN	APPD	DATE

DESIGNED	I.ERNST
DRAWN	I.ERNST
CHECKED	N.GREEN
APPROVED	







PROJECT	PROPOSED DEVELOPMENT 67 & 69 SHORE STREET EAST CLEVELAND, QLD, 4163.
DISCIPLINE	CIVIL

STATUS	PRELIMINARY ISSUE			
SHEET TITLE	CONCEPT EARTHWORKS LAYOUT			
PROJECT NUMBER	23191	DRAWING NUMBER	23191-DWG-CV-CV-SK010	REV B

NOT FOR CONSTRUCTION

LEGEND


	DESIGN SURFACE
	BULK EARTHWORKS SURFACE
	DATUM LINE
	EXISTING SURFACE
	PROPOSED RETAINING WALL
	PROPOSED SURFACE SLOPE



VERGE TO GRADE AT 3% TO BACK OF PROPOSED
FOOTPATH IN ACCORDANCE WITH COUNCIL
STANDARDS BEFORE GRADING BACK TO EXISTING
SURFACE LEVELS AT PROPERTY BOUNDARY AT
VARYING GRADES OF APPROX. 10%.

NOT FOR CONSTRUCTION

Appendix 2. Development site and SPS 002 sewer catchment



LEGEND

- Trunk gravity main
- Retic. gravity main
- Rising main
- Flow path
- SPS
- Development site
- SPS 002 catchment
- Property boundary

H2One Pty Ltd
PO Box 23
KALBAR Q 4309
P: (07) 5463 9538
E: Info@H2One.com.au
W: h2one.com.au

Important Notice!
This map is not a precise survey document. Accurate locations can only be determined by a survey on the ground.

H2One Pty Ltd gives no warranty in relation to the data (including accuracy, reliability, completeness or suitability) and accepts no liability (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data.

DESIGNED:
D Colledge

DRAWN:
D Colledge

CHECKED:
J May

APPROVED:
J May

CLIENT PM:

H2ONE PM:
J May

NOTE: DESIGN NOT TO BE AMENDED WITHOUT
H2ONE PTY LTD ACCEPTANCE

A

ORIGINAL ISSUE - 21 JUN, 2024

No.

REVISION

APPROVED

DATUM:
HORIZ: MGA94 (ZONE 56)
HEIGHT: AHD

SCALE:
0 100 200
Metres

SURVEYED BY / DATE: SURVEY CHECKED:

PROJECT NO:
2405622

FILE REF:

CAD FILE:

REDLAND CITY COUNCIL
PO BOX 21
CLEVELAND QLD 4163

67-69 Shore St E
Cleveland QLD 4163
Water Supply and Sewerage
Network Capacity Assessment


Appendix 2. Development site
and SPS 002 sewer catchment

JUN, 2024

DATE SCANNED:

DRG No: REV:

Appendix 3. Development site and Alexandra Hills water supply system





H2ONE

H2One Pty Ltd
PO Box 23
KALBAR QLD 4309

P: (07) 5463 9538
E: Info@H2One.com.au
W: h2one.com.au

DESIGNED: D Colledge	NOTE: DESIGN NOT TO BE AMENDED WITHOUT H2ONE PTY LTD ACCEPTANCE	
DRAWN: D Colledge		
CHECKED: J May		
APPROVED: J May		
CLIENT PM:		
H2ONE PM: J May	A	ORIGINAL ISSUE - 21 JUN, 2024
	No.	REVISION
		APPROVED

DATUM:
HORIZ: MGA94 (ZONE 56)
HEIGHT: AHD

SCALE:
0 325 650
Metres

SURVEYED BY / DATE: SURVEY CHECKED:

H2ONE REFERENCES	
PROJECT NO: 2405622	
FILE REFERENCE:	
CAD FILE:	



REDLAND CITY COUNCIL
PO BOX 21, CLEVELAND QLD 4163

**67-69 Shore St E
Cleveland QLD 4163
Water Supply and Sewerage
Network Capacity Assessment**


Appendix 3. Development site and
Alex. Hills LLZ water supply system

ORIGINAL ISSUE DATE: JUN, 2024	
DATE SCANNED:	
DRG No:	REV:


Important Notice!
This map is not a precise survey document. Accurate locations can only be determined by a survey on the ground.

H2One Pty Ltd gives no warranty in relation to the data (including accuracy, reliability, completeness or suitability) and accepts no liability (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data.

Appendix 4. Pump capacity assessment results



SPS 002 @ Ultimate



Appendix 5. Operational storage capacity assessment results

		2021	Ultimate
Single Pump Capacity Required	C1	4.77	3.76
	ADWF (L/s)	3.32	14.98
	Q (L/s)	15.83	56.26
Storage Capacity Required	Pump Setup	Duty-assist	Duty-assist
	Duty Head (m)	NA	NA
	Pump Efficiency (%)	NA	NA
	Duty Power (kW)	<100.00	<100.00
	No. pump starts (n)	12.00	12.00
	Volume (kL)	1.19	4.22
Storage Capacity Available	Duty Start (RL m)	-3.07	-3.07
	Duty Stop (RL m)	-3.22	-3.22
	Duty Height (m)	0.15	0.15
	WW Diam. (m)	2.00	2.00
	Volume (kL)	0.47	0.47
OUTCOME	Difference (kL)	-0.72	-3.75
	Pass / Fail	FAIL	FAIL


Note 1: Wet well and pump details were sourced from the RCC's hydraulic model.

Note 2: The above table shows results at post-development.

Note 3: The storage deficiencies can be resolved, up to the 2031 planning horizon, by increasing the duty pump start level to the invert level of the discharging gravity main (RL -2.66 m). Subsequent planning horizons may require a storage upgrade.

Appendix 6. Gravity main capacity assessment results

SPS 002 @ 2021, Pre-development



SPS 002 @ 2021, Post-development



SPS 002 @ Ultimate, Pre-development



SPS 002 @ Ultimate, Post-development



Appendix 7. Emergency storage capacity assessment results

SPS 002 Overflow RL: RL 1.95 m @ node 43077 - 0.3 m = RL 1.65 m

MH Volume Below RL 1.65 m @ 1.05 m Diameter: 24.5 kL

Wet Well Volume Between Duty Start (RL -3.07 m) and Overflow @ 2.0 m Diameter: 14.8 kL

Gravity Main Volume Below RL 1.65 m: 18.5 kL (2021) and 32.9 kL (2026-Ultimate)

Total Available Volume (2021): 24.5 + 14.8 + 18.5 = 57.9 kL

Total Available Volume (Ultimate): 24.5 + 14.8 + 32.9 = 72.2 kL

Total Volume Required @ 4 hours ADWF (2021): 1,002.7 EP (post-develop.) x 210 L/EP/day = 35.1 kL

Total Volume Required @ 4 hours ADWF (2026): 1,889.3 EP (post-develop.) x 210 L/EP/day = 66.1 kL

Total Volume Required @ 4 hours ADWF (2031): 2,997.7 EP (post-develop.) x 210 L/EP/day = 104.9 kL

Total Volume Required @ 4 hours ADWF (ULT): 5,455.7 EP (post-develop.) x 210 L/EP/day = 190.9 kL

In summary, compliance is achieved for 2021 and 2026 only, i.e. 35.1 kL versus 57.9 kL, and 66.1 kL versus 72.2 kL, respectively. A storage upgrade (total of 190.9 kL) will likely be required to achieve 4 hours ADWF.

Note the available catchment storage does not consider existing ADWF already within the pipe/MH network. Results should therefore be considered an estimate only.