

Riverbend, Qld - Precinct 1

Water Supply and Sewer Precinct Network Plan (PNP) Modelling Assessment

FINAL Report V1 - 24 March, 2026



H2One Pty Ltd

Water, Sewer and Stormwater Engineering Specialists

H2One Pty Ltd

ABN 20 130 354 764

P 07 5463 9538

E info@H2One.com.au

W h2one.com.au

Reviewed by RPEQ	Reg. No.	Signed	Date
Joshua May	18064		24 March, 2026

Version	Date	Author	Reviewer
DRAFT - V1	24 March, 2026	J Meesamphan	J May
FINAL - V1	24 March, 2026	J Meesamphan	J May

Copyright in the whole and every part of this document belongs to H2One Pty Ltd and may not be used, sold, transferred, copied or reproduced in whole or in part in any manner or form or in or on any media to any person without the prior written approval of H2One Pty Ltd.

TABLE OF CONTENTS

1 INTRODUCTION 2

 1.1 Background 2

 1.2 Objectives..... 3

 1.3 Demand Assessment 3

2 METHODOLOGY 5

 2.1 Desired Standards of Service 5

 2.2 Hydraulic Modelling Assessment 5

 2.2.1 Sewer Network 5

 2.2.2 Water Supply Network 6

3 RESULTS 8

 3.1 Sewer Precinct Network Plan (PNP)..... 8

 3.2 Water Supply Precinct Network Plan (PNP) 11

4 CONCLUSION..... 14

5 REFERENCE LIST 16

6 APPENDICES 17

 Appendix 1. Riverbend Precinct 1 development and staging layout plans 18

 Appendix 2. LCC Desired Standards of Service 19

 Appendix 3. Riverbend sewer trunk pipeline design plans 21

 Appendix 4. Sewer network modelling results..... 22

 Appendix 5. Water supply network modelling results 53

1 INTRODUCTION

1.1 Background

Colliers Pty Ltd developed a water supply and sewer Precinct Network Plan (PNP) for Precinct 1 of the 'Riverbend' property, located within the broader Flagstone Priority Development Area (PDA). This was to progress initial development of the properties owned by Celestino Development Pty Ltd, consisting of Lots 101, 102, 104, 105 and 106 on SP254145 and Lot 800 on SP247625, as shown in Figure 1 below.



Figure 1. Location of the ultimate development area (Source: Colliers Pty Ltd, 2024)

Economic Development Queensland (EDQ) requested a modelling assessment of the “Riverbend, Precinct 1” PNP, to confirm the overall service strategy and size of relevant infrastructure. A summary of the service strategy developed by Colliers Pty Ltd and H2One Pty Ltd, as part of this study, is presented below. Refer to Appendix 1 for the layout and staging plan of Precinct 1.

- **Sewer:** Precinct 1 will be serviced by a DN150 to DN525 gravity sewer network discharging to two (2) Sewer Pump Stations (SPS). The primary SPS, located to the eastern side of the site, will convey the full catchment loading directly to the Sewage Treatment Plant (STP) situated south of the Logan River. A secondary, smaller SPS will be constructed to the north to service areas where surface levels fall away from the central SPS catchment.

The central SPS, together with the upstream trunk gravity system, is intended to ultimately service the broader Riverbend development at ultimate build-out.

- **Water Supply:** Precinct 1 will be serviced via dual DN375 and DN300 PVC trunk water mains constructed within the primary road corridor through the development site, extending south from the existing DN375 main along Teviot Road. A Pressure Reducing Valve (PRV) will regulate supply to the internal reticulation network, effectively establishing Precinct 1 as a single District Metered Area (DMA).

At ultimate development, the broader Riverbend area is intended to operate under approximately eight DMA's. The lower-lying areas will be supplied from the future Flagstone

storage reservoirs located west of Riverbend, while the elevated areas will be supplied from the Round Mountain reservoir to the north. A temporary booster pump station is proposed to service the higher-elevation properties until the Flagstone reservoirs are constructed (currently anticipated around 2040).

Riverbend Precincts 1 and 2 will be gravity supplied from the Round Mountain reservoir, with the temporary booster pump station to be implemented from the progression of Precinct 3.

On behalf of Colliers Pty Ltd, H2One Pty Ltd was engaged to undertake a modelling assessment of the proposed PNP’s, in accordance with Logan Water Alliance’s (LWA) minimum Desired Standards of Service (DSS), refer to Appendix 2 for relevant details. The results of the study are presented in this report.

1.2 Objectives

The main objectives of the project were as follows.

1. Introduce the proposed PNP’s to LCC’s latest InfoWorks planning models, at the 2031 planning horizon.
2. Undertake a hydraulic analysis of the proposed PNP’s to confirm feasibility and size relevant assets, as per LWA’s minimum Desired Standards of Service.
3. Report on findings.

1.3 Demand Assessment

A demand assessment of the development was undertaken to determine the approximate potable water and sewage demands attributed to the proposed land-use type and density. This was calculated using LCC’s adopted Equivalent Person (EP) unit rates and average “per capita” demands for potable water @ 190 L/EP/day, and sewage @ 165 L/EP/day. A summary of the estimated site demands are as follows.

Table 1. Estimated water supply and sewage demands for Precinct 1

Site Land Use and Density	Demand Rate	EP	Water Supply		Sewage	
			AD (L/s)	PH (L/s)	ADWF (L/s)	PWWF (L/s)
855 x res. freehold lots	2.8 EP/lot	2,394.0	5.26	14.87	4.57	22.86
119 x MDR lots	2 EP/dwel.	238.0	0.52	1.48	0.45	2.27
Primary school 14,100 m ² GFA	0.66 EP/100 m ² GFA	94.0	0.21	0.58	0.18	0.90
TOTAL		2,726.0	5.99	16.93	5.21	26.03

Note 1: For water supply, demand estimates were based on 165 L/EP/day, with 25 L/EP/day non-revenue water. AD to PH factor of 3.1.

Note 2: For sewage, discharge estimates are based on 165 L/EP/day for ADWF and 1,000 L/EP/day for PWWF.

Note 3: Demand estimates for the residential freehold lots and medium density residential (MDR) lots are based on the latest staging plans for Precinct 1 (refer to Appendix 1). School demands were sourced from the Water Supply and Sewer Infrastructure Master Plan (IMP) report (2025), prepared by H2One Pty Ltd.

As previously discussed, this study was undertaken on the 2031 planning horizon, as it is relevant to early stages of development (Precinct 1) for Riverbend. The ultimate Riverbend catchment area has already been assessed and approved via the Infrastructure Master Plan (IMP). PNP’s will be developed in due course for precincts subsequent to that of Precinct 1.

LCC's hydraulic models had no planning demands (EP) allocated to the subject site at the 2031 planning horizon, therefore the demands in Table 1 were simply introduced to the models, with no changes to the native demand set.

2 METHODOLOGY

2.1 Desired Standards of Service

The minimum DSS adopted for the hydraulic assessment were based on LWA’s latest DSS, issued by LWA for the purpose of this study. A summary of the relevant provisions is as follows, refer to Appendix 2 for further details.

Table 2. DSS adopted for the modelling assessment

	Provision	Specification
Sewerage	Average Dry Weather Flow (ADWF)	165 L/EP/day
	Peak Wet Weather Flow (PWWF)	1000 L/EP/day (residential) 840 L/EP/day (non-residential)
	Single pump capacity	C1 x ADWF (L/s) where; C1 = 3.5 to 5.0 C1 = 15 x (EP) ^{-0.1587}
	Pump station operational storage (kL)	0.9 x Q / N where; Q = Single pump capacity (L/s) N = Number of pump starts per hour, where N = 12 for duty pump motor < 100 kW N = 8 for duty pump motor 100 – 200 kW N = 5 for duty pump motor > 200 kW
	Pump station emergency storage (kL)	4 hours ADWF
	Total pump station capacity (L/s)	PWWF
	Maximum depth of gravity flow (proposed gravity mains)	75% pipe diameter
	Maximum pressure main flow velocity	3.0 m/s
Water Supply	Average Day Demand	165 L/EP/day consumption + 25 L/EP/day leakage/loss
	Maximum trunk pipe flow velocity	2.5 m/s
	Standard flow minimum network pressure and background demand	22m at the property boundary at PH demand (on demand area) 10m at the property boundary at PH demand (constant flow area)
	Residential fire flow minimum network pressure and background demand	12m at 2/3 PH demand for on demand areas Reservoir at Minimum Operating Level (15%)
	Fire flows	Residential - 15L/s for 2 hours Commercial/industrial - 30L/s for 4 hours

2.2 Hydraulic Modelling Assessment

2.2.1 Sewer Network

The methodology adopted for the assessment of the sewer PNP is as follows.

1. LCC issued the “IP0022 Logan South Master Plan” InfoWorks ICM hydraulic model to H2One Pty Ltd, and permitted its use for planning assessments. The scenario adopted for the assessment of the ultimate development was “A_LS22_2031_Mains_Load_2031”.

2. The proposed sewer network was translated to shape files and introduced to the hydraulic model as a background layer. Manholes, pipes, pump stations etc. were drawn manually and relevant data entered for each element. The shape files were sourced from the latest DWG design files provided by Colliers Pty Ltd.
3. Property demands (EP) were distributed within the model based on lots draining to the minor pump station located in the northern area of Precinct 1, and the remaining network gravitating to the primary pump station central to the ultimate Riverbend catchment. Details are as follows.
 - Northern SPS catchment @ 909 EP: 260 × residential freehold lots, 68 × MDR dwellings, and Primary School Connection 1
 - Central SPS catchment @ 1,817 EP: 595 × residential freehold lots, 51 × MDR dwellings, and Primary School Connection 2

Within each catchment, demands associated with single-family residential (SFR) lots were distributed evenly across model manholes, with preference given to upstream nodes to provide a conservative assessment of gravity pipe capacity.

For the MDR lots and primary school site, demands were assigned to the nearest manhole, representing the most likely connection locations. Given the large footprint of the school site, the demand was distributed across two on-site manholes to reflect the likelihood of multiple sewer connections.

The MDR demand allocations were based on the proportional land area of each lot relative to the total number of dwellings (119) identified in the staging plans (refer to Appendix 1). This resulted in the following EP allocations:

- Northern MDR lot @ 0.69 ha (26%): 61.3 EP
 - Central MDR lot @ 0.82 ha (31%): 72.8 EP
 - Southern MDR lot @ 1.17 ha (44%): 103.9 EP
4. The surface levels were also added to each node, in addition to pipe invert levels based on LWA's minimum grade requirements (refer below) and assumed minimum ground cover of 900 mm from the surface level.
 - DN150 @ 1:180
 - DN225 @ 1:290
 - DN375 @ 1:550
 - DN450 @ 1:700
 - DN525 @ 1:900

The trunk gravity pipeline upstream of the proposed central pump station was sourced from Colliers design plans (refer to Appendix 3 for the relevant design plans).

5. A final review of the model setup was undertaken and any identified errors rectified.
6. For the ultimate sewer network of Precinct 1, a hydraulic capacity assessment was undertaken on the gravity pipes, where identified deficiencies were resolved via changes to the overall PNP, e.g. increase in pipe size, changes to pipe alignments etc.
7. Modelling results were reviewed and findings reported.

2.2.2 Water Supply Network

The methodology adopted for the assessment of the water supply PNP is as follows.

1. LCC issued the “PL-2022-01” InfoWorks WS Pro hydraulic model to H2One Pty Ltd, and permitted its use for the assessment. The scenarios adopted for the assessment of Precinct 1 was “2031”.
2. The proposed water supply network was translated to shape files and introduced to the hydraulic model as a background layer. Nodes, pipes, pump station etc. were drawn manually and relevant data entered for each element. The shape files were sourced from the latest DWG design files provided by Colliers Pty Ltd.
3. All pipes were assigned the relevant diameter and Colebrook–White roughness coefficient of 0.06 mm for PVC and 0.3 mm for DICL. It was assumed that all trunk mains and pipes crossing major road corridors were DICL with a roughness coefficient of 0.3 mm. Nominal pipe diameter was assumed to be equal to the internal diameter, which was considered acceptable given the network will be predominantly constructed of PVC pipe.

Surface levels were assigned to each node based on the design levels, and the total site demand (2,726 EP) was evenly distributed across the relevant nodes on the reticulation network, with exception of the MDR sites and the school which was allocated to the nearest node.

4. A review of the model setup was undertaken and any identified errors were rectified.
5. A standard flow and fire flow (15 L/s at 2/3 peak hour demand) modelling analysis was undertaken to appropriately size the proposed pipework at each development stage. Any network deficiencies identified during the analysis were addressed by increasing pipe diameters and/or improving network connectivity.

An assessment of the external network was not undertaken, as this was addressed in detail within the recent IMP report. The IMP assessment utilised the same hydraulic model, planning horizon, service strategy, and a similar EP estimate for Precinct 1.

6. Modelling results were reviewed and findings reported.

3 RESULTS

3.1 Sewer Precinct Network Plan (PNP)

The proposed sewer PNP was modelled for Precinct 1, as per the design drawings prepared by Colliers Pty Ltd. The hydraulic analysis determined the following.

- All gravity pipes operated below the 75% d/D flow depth requirement, with the maximum being 64.3% for the DN150 gravity mains between node P1-MH10 and P1-MH8.
- The proposed sewer network will comprise approximately 11.8 km of gravity pipes and 600 m of pressure pipes, excluding the downstream system beyond the proposed central pump station, which will be delivered by Logan City Council (LCC). A summary of the proposed sewer infrastructure required to service the development is provided in Table 3.

Table 3. Summary of proposed sewer infrastructure to service Precinct 1

Description	Location	Pipe Diameter (DN mm)	Length (m)
Northern SPS (minor)	Northern extremity of Precinct 1	N/A	N/A
Central SPS (minor) – to be delivered by LCC	Eastern extremity of Precinct 1	N/A	N/A
Rising main downstream of minor northern SPS	Northern area of Precinct 1	100	600
Retic. gravity pipe	Throughout Precinct 1	150	10,100
Trunk gravity pipe	Pipeline downstream of the northern (minor) SPS discharge	225	740
Trunk gravity pipe	Primary pipeline grading west to east towards the central (major) pump station	375	200
Trunk gravity pipe	Primary pipeline grading west to east towards the central (major) pump station	450	420
Trunk gravity pipe	Primary pipeline grading west to east towards the central (major) pump station	525	320


- The gravity trunk main is estimated to reach a maximum depth of approximately 9.2 m below ground level within the DN525 pipeline immediately upstream of the central SPS. The maximum depth within the reticulation network is estimated at 3.8 m at manhole P1-MH75, located on the DN225 pipeline upstream of the northern SPS.
- The northern SPS is estimated to require a wet well depth of approximately 4.0 m. The pump station is assumed to comprise two pumps operating in a duty–standby configuration, with an estimated duty point of 11.5 L/s at approximately 32.0 m total pressure head.

This duty point is based on a static head of approximately 18.0 m (RL 39.0 m to RL 57.0 m) and an estimated friction loss of approximately 14.0 m within the DN100 rising main over a length of approximately 600 m.

Under single duty-standby pump operation, the anticipated flow velocity within the DN100 rising main is approximately 1.3 m/s, which is in compliance with minimum velocity requirements.

Final pump selection and motor sizing will be undertaken during the detailed design stage.

Refer to Figure 2 below for a schematic of the proposed sewer network and Appendix 4 for detailed modelling results.



LEGEND

- DN525 GM
- DN450 GM
- DN375 GM
- DN225 GM
- DN150 GM
- - - DN100 RM
- SPS
- Manhole
- Property boundary

H2ONE

H2One Pty Ltd
PO Box 23
KALBAR Q 4309

P: (07) 5463 9538
E: Info@H2One.com.au
W: h2one.com.au

Important Notice!
This map is not a precise survey document. Accurate locations can only be determined by a survey on the ground.

H2One Pty Ltd gives no warranty in relation to the data (including accuracy, reliability, completeness or suitability) and accepts no liability (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data.

DESIGNED: J Meesamphan	NOTE: DESIGN NOT TO BE AMENDED WITHOUT H2ONE PTY LTD ACCEPTANCE	
DRAWN: J Meesamphan		
CHECKED: J May		
APPROVED: J May		
CLIENT PM:	A	ORIGINAL ISSUE - 24 MAR 2026
H2ONE PM: J May	No.	REVISION APPROVED

DATUM:
HORIZ: MGA94 (ZONE 56)
HEIGHT: AHD

SCALE:
0 65 130
Metres

SURVEYED BY / DATE: SURVEY CHECKED:

PROJECT NO: 2411668	Logan City Council PO Box 3226 Logan City DC QLD 4114
FILE REF:	
CAD FILE:	

**Precinct 1 - Riverbend QLD
Water Supply and Sewer
PNP Modelling Assessment**

Figure 2. Concept layout of the sewer PNP for Precinct 1

MAR, 2026	DATE SCANNED:
DRG No:	REV:

3.2 Water Supply Precinct Network Plan (PNP)

The proposed water supply PNP was modelled at ultimate development of Precinct 1, with a subsequent staging analysis to ensure minimum DSS are achieved at each development stage. This was undertaken on the basis that the future “MPR-T1002” and “MPR-T1005” Flagstone storage tanks are not yet operational. Key outcomes are as follows.

- The proposed water supply network will consist of approximately 16.7 km’s of water supply mains. Refer to Table 4 below for further details.

Table 4. Summary of proposed water supply infrastructure to service the development

Description	Location	Pipe Diameter (DN mm)	Length (m)
Retic. water pipe	Throughout Precinct 1	DN100	6,900
Retic. water pipe	Throughout Precinct 1	DN150	6,050
Trunk water pipe	Primary road running west to east	DN250	1,870
Trunk water pipe	Primary road access running north to south from Teviot Rd	DN300	1,050
Trunk water pipe	Primary road access running north to south from Teviot Rd	DN375	840

- Across all development scenarios for Precinct 1, the minimum standard flow and fire flow pressures were 34.6 m (node P1-53) and 40.1 m (node P1-85), respectively. These results comply with LWA’s minimum pressure requirements of 22 m under standard flow and 12 m under fire flow conditions.
- The maximum pipe velocity recorded within the network was 0.7 m/s, with a maximum friction loss of 3.13 m/km occurring in pipe “P1-11.P1-92.1”. Both values are within LWA’s design criteria.
- The planned DN300 and DN375 trunk mains along the primary road corridor are anticipated to be installed as part of Stage 4 development. In the interim, a DN150 connection is proposed at the entrance to Stage 1 to supply the reticulation network servicing Stages 1 to 3. This arrangement will remain in place until the trunk mains are constructed, at which point the connection will be closed with the establishment of the DMA boundary. This connection is planned to remain permanent and provide an additional level of redundancy to the local network.
- As identified in H2One’s Riverbend IMP report, the Water Treatment Plant (WTP) pump station located immediately south of Riverbend is critical to the performance of the wider Round Mountain supply network. This is because the Round Mountain tanks do not have sufficient head to overcome friction losses through the existing trunk main system.

This was further confirmed through the assessment of the Precinct 1 PNP, where the WTP pumps were required to operate during the peak demand event to maintain minimum pressures within both Riverbend and the wider network. For example, approximately 45 nodes within Precinct 1 experienced a momentary drop below the minimum standard flow pressure requirement (22 m), with the lowest pressure observed at 13.0 m.

It is therefore recommended that LWA ensures appropriate operational controls (e.g. pressure controls) are in place at the WTP pump station, prior to the installation of the Flagstone storage tanks. Operation of the pumps based solely on reservoir levels may not be

sufficient under certain demand conditions, such as when the tanks are full and a temporary increase in peak demand occurs.

- Precinct 1 will include the construction of trunk pipelines that will initially experience limited utilisation, as these assets are being installed in readiness to service subsequent precincts. To mitigate potential water quality issues associated with low flows, it is recommended that a scheduled flushing program be implemented following commissioning of the assets and/or temporary cross-connections to the reticulation network be constructed to promote improved network circulation.

Refer to Figure 3 below for the proposed water supply PNP layout, and Appendix 5 for detailed modelling results.



Interim Connection to Existing
DN375 to Service Stages 1 to 3
(Closed at Establishment of DMA)

MDR
(North)

Connection to Existing
DN375 along Teviot Rd

Teviot Rd

Primary School

MDR
(Central)

MDR
(South)

LEGEND

- DN375 WM
- DN300 WM
- DN250 WM
- DN150 WM
- DN100 WM

Property boundary

H2ONE


H2One Pty Ltd
PO Box 23
KALBAR Q 4309
P: (07) 5463 9538
E: Info@H2One.com.au
W: h2one.com.au

DESIGNED:
J Meesamphan
DRAWN:
J Meesamphan
CHECKED:
J May
APPROVED:
J May
CLIENT PM:
H2ONE PM:
J May

NOTE: DESIGN NOT TO BE AMENDED WITHOUT
H2ONE PTY LTD ACCEPTANCE

No.	REVISION	APPROVED
A	ORIGINAL ISSUE - 24 MAR 2026	

DATUM:
HORIZ: MGA94 (ZONE 56)
HEIGHT: AHD



SURVEYED BY / DATE: SURVEY CHECKED:

PROJECT NO:
2411668

FILE REF:

CAD FILE:

Logan City Council
PO Box 3226
Logan City DC QLD 4114

MAR, 2026

DATE SCANNED:

DRG No: REV:

**Precinct 1 - Riverbend QLD
Water Supply and Sewer
PNP Modelling Assessment**

Figure 3. Concept layout of the
water supply PNP for Precinct 1

Important Notice!
This map is not a precise survey document. Accurate locations can only be determined by a survey on the ground.
H2One Pty Ltd gives no warranty in relation to the data (including accuracy, reliability, completeness or suitability) and accepts no liability (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data.

4 CONCLUSION

Colliers Pty Ltd developed a water supply and sewer Precinct Network Plan (PNP) for Precinct 1 of the 'Riverbend' property, located within the broader Flagstone Priority Development Area (PDA). This was to progress initial development of the properties owned by Celestino Development Pty Ltd, consisting of Lots 101, 102, 104, 105 and 106 on SP254145 and Lot 800 on SP247625, as shown in Figure 4 below.



Figure 4. Location of the ultimate development area (Source: Colliers Pty Ltd, 2024)

Economic Development Queensland (EDQ) requested a modelling assessment of the “Riverbend, Precinct 1” PNP, to confirm the overall service strategy and confirm sizing of the relevant infrastructure. A summary of the service strategy developed by Colliers Pty Ltd and H2One Pty Ltd, as part of this study, is presented below.

- **Sewer:** Precinct 1 will be serviced by a DN150 to DN525 gravity sewer network discharging to two (2) Sewer Pump Stations (SPS). The primary SPS, located to the eastern side of the site, will convey the full catchment loading directly to the Sewage Treatment Plant (STP) situated south of the Logan River. A secondary, smaller SPS will be constructed to the north to service areas where surface levels fall away from the central SPS catchment.

The central SPS, together with the upstream trunk gravity system, is intended to ultimately service the broader Riverbend development at ultimate build-out.

- **Water Supply:** Precinct 1 will be serviced via dual DN375 and DN300 PVC trunk water mains constructed within the primary road corridor through the development site, extending south from the existing DN375 main along Teviot Road. A Pressure Reducing Valve (PRV) will regulate supply to the internal reticulation network, effectively establishing Precinct 1 as a single District Metered Area (DMA).

At ultimate development, the broader Riverbend area is intended to operate under approximately eight DMA's. The lower-lying areas will be supplied from the future Flagstone storage reservoirs located west of Riverbend, while the elevated areas will be supplied from

the Round Mountain reservoir to the north. A temporary booster pump station is proposed to service the higher-elevation properties until the Flagstone reservoirs are constructed (currently anticipated around 2040).

Riverbend Precincts 1 and 2 will be gravity supplied from the Round Mountain reservoir, with the temporary booster pump station to be implemented from the progression of Precinct 3.

On behalf of Colliers Pty Ltd, H2One Pty Ltd was engaged to undertake a modelling assessment of the proposed PNP's, in accordance with Logan Water Alliance's (LWA) minimum Desired Standards of Service (DSS). The hydraulic analysis identified that the proposed PNP's should theoretically operate within LWA's minimum design standard, prior to the installation of the Flagstone Tanks anticipated for the 2041 planning horizon.

It is therefore recommended that EDQ and LWA review the PNP's presented in this report and approve the general service strategy and infrastructure sizing. The findings in this report were based on LWA's latest planning model and may not consider recent changes to infrastructure and/or development timing within the greater Flagstone area.

Detailed modelling results and concept layout plans can be observed in Appendices 1 through 5.

5 REFERENCE LIST

LWA. (2025). *Desired Standards of Service*. Logan City QLD

Colliers Pty Ltd. (2024) *Riverbend Water and Wastewater Infrastructure Master Plan*. Buddina QLD

H2One Pty Ltd. (2025) *Riverbend, Qld Water Supply and Sewer Infrastructure Master Plan (IMP) Modelling Assessment*. Sunshine Coast QLD

6 APPENDICES

Appendix 1. Riverbend Precinct 1 development and staging layout plans

PROJECT

RIVERBEND

CLIENT



NOTES

ALL LOT NUMBER AND DIMENSIONS (INCLUDING AREAS) ARE APPROXIMATE ONLY AND SUBJECT TO FURTHER DESIGN DEVELOPMENT.

ALL DIMENSIONS HAVE BEEN ROUNDED TO THE NEAREST 0.1 METRES AND ALL AREAS HAVE BEEN ROUNDED TO THE NEAREST SQUARE METRE.

THE BOUNDARIES ON THIS PLAN SHOULD NOT BE USED FOR THE FINAL DESIGN AND ARE SUBJECT TO FINAL DETAILED DESIGN BY ENGINEERS.

INFORMATION ON THIS PLAN ARE FROM THE FOLLOWING SOURCES:

SITE BOUNDARIES: COLLIERS (JANUARY 2026)
ADJOINING CADASTRE: QSPATIAL
DESIGN CONTOURS: COLLIERS (FEBRUARY 2026)
EXISTING CONTOURS: COLLIERS (JANUARY 2026)

ISSUE CODE	ISSUE DESCRIPTION	BY	CHK	DATE
-	PRE DRAFT ISSUE	NV	NV	05/09/2025
A	PRE DRAFT ISSUE	NV	NV	12/09/2025
B	PRE FINAL ISSUE	NV	NV	30/09/2025
C	PRE DRAFT ISSUE	NV	NV	02/02/2026
D	PRE FINAL ISSUE	NV	NV	04/03/2026
E	PRE FINAL ISSUE	NV	NV	10/03/2026
F	PRE FINAL ISSUE	NV	NV	12/03/2026

PRE - Preliminary | CA - Council Approval | T - Tender | CON - Construction

DRAWING TITLE


PRECINCT 1 -
OVERALL PRECINCT 1

DESIGN : TD
DOCUMENT : TD / NV
PROJECT : 4123001
1:15,000 @ A3



0 200 400 600

DRAWING NUMBER : 4123001 - 26
REVISION : F



Legend:

- Site boundary
- Precinct boundary
- Existing road reserve

Key Plan (road reserves)
1:10,000 @ A3

PROJECT

RIVERBEND

CLIENT



NOTES

ALL LOT NUMBER AND DIMENSIONS (INCLUDING AREAS) ARE APPROXIMATE ONLY AND SUBJECT TO FURTHER DESIGN DEVELOPMENT.

ALL DIMENSIONS HAVE BEEN ROUNDED TO THE NEAREST 0.1 METRES AND ALL AREAS HAVE BEEN ROUNDED TO THE NEAREST SQUARE METRE.

THE BOUNDARIES ON THIS PLAN SHOULD NOT BE USED FOR THE FINAL DESIGN AND ARE SUBJECT TO FINAL DETAILED DESIGN BY ENGINEERS.

INFORMATION ON THIS PLAN ARE FROM THE FOLLOWING SOURCES:

- SITE BOUNDARIES: COLLIERS (JANUARY 2026)
- ADJOINING CADASTRE: QSPATIAL
- DESIGN CONTOURS: COLLIERS (FEBRUARY 2026)
- EXISTING CONTOURS: COLLIERS (JANUARY 2026)


ISSUE	CODE	ISSUE DESCRIPTION	BY	CHK	DATE
-	PRE	DRAFT ISSUE	NV	NV	05/09/2025
A	PRE	DRAFT ISSUE	NV	NV	12/09/2025
B	PRE	FINAL ISSUE	NV	NV	30/09/2025
C	PRE	DRAFT ISSUE	NV	NV	02/02/2026
D	PRE	FINAL ISSUE	NV	NV	04/03/2026
E	PRE	FINAL ISSUE	NV	NV	10/03/2026
F	PRE	FINAL ISSUE	NV	NV	12/03/2026

PRE - Preliminary | CA - Council Approval | T - Tender | CON - Construction


DRAWING TITLE

PRECINCT 1 -
STAGING PLAN

DESIGN : TD
DOCUMENT : TD / NV
PROJECT : 4123001
1:6,000 @ A3




DRAWING NUMBER : 4123001 - 27
REVISION : F



PRECINCT 1
73.43 ha

Residential Net Density Precinct 1	Calculation **		Rate
	Area (ha) **	Total Lots/Dwellings	
Stage 1A	3.04	50	16.45
Stage 1B	0.78	29	37.18
Stage 2	4.06	60	14.78
Stage 3	4.43	69	15.58
Stage 4	5.69	119	20.91
Stage 5	3.76	74	19.68
Stage 6 (School)	0	0	N/A
Stage 7	5.81	124	21.34
Stage 8	6.50	100	15.38
Stage 9	3.86	83	21.50
Stage 10	3.97	90	22.67
Stage 11	8.55	176	20.58
Stage 12 (Temp. Stormwater Basin)	0	0	N/A
Precinct 1 Total	50.45	974	19.31

- Legend:
- Site boundary
 - Precinct boundary
 - Stage boundary



** EDQ PDA Guideline No. 01 (Residential 30) definition of net residential density: the number of residential lots/dwellings divided by the area of residential lots/dwellings, local roads and local parks

PROJECT

RIVERBEND

CLIENT



NOTES

ALL LOT NUMBER AND DIMENSIONS (INCLUDING AREAS) ARE APPROXIMATE ONLY AND SUBJECT TO FURTHER DESIGN DEVELOPMENT.

ALL DIMENSIONS HAVE BEEN ROUNDED TO THE NEAREST 0.1 METRES AND ALL AREAS HAVE BEEN ROUNDED TO THE NEAREST SQUARE METRE.

THE BOUNDARIES ON THIS PLAN SHOULD NOT BE USED FOR THE FINAL DESIGN AND ARE SUBJECT TO FINAL DETAILED DESIGN BY ENGINEERS.

INFORMATION ON THIS PLAN ARE FROM THE FOLLOWING SOURCES:

SITE BOUNDARIES: COLLIERS (JANUARY 2026)
ADJOINING CADASTRE: QSPATIAL
DESIGN CONTOURS: COLLIERS (FEBRUARY 2026)
EXISTING CONTOURS: COLLIERS (JANUARY 2026)

ISSUE	CODE	ISSUE DESCRIPTION	BY	CHK	DATE
-	PRE	DRAFT ISSUE	NV	NV	05/09/2025
A	PRE	DRAFT ISSUE	NV	NV	12/09/2025
B	PRE	FINAL CONSULTANT ISSUE	NV	NV	24/09/2025
C	PRE	FINAL CONSULTANT ISSUE	NV	NV	26/09/2025
D	PRE	FINAL ISSUE	NV	NV	30/09/2025
E	PRE	DRAFT ISSUE	NV	NV	02/02/2026
F	PRE	FINAL ISSUE	NV	NV	04/03/2026
G	PRE	FINAL ISSUE	NV	NV	10/03/2026
H	PRE	FINAL ISSUE	NV	NV	12/03/2026

PRE - Preliminary | CA - Council Approval | T - Tender | CON - Construction

DRAWING TITLE

PRECINCT 1 -
PLAN OF SUBDIVISION


DESIGN : TD
DOCUMENT : TD / NV
PROJECT : 4123001
1:6,000 @ A3



0 50 100 150 200


DRAWING NUMBER REVISION
4123001 - 28 H

Yield Summary Precinct 1 Summary	Typical Dimensions	Typical Area	Precinct 1		
			No. of Lots	%	Area (ha)
Lot Type					
30m Deep Attached (Terrace) Allotment (30 dw/ha)					
7.5m Front-Loaded Terrace Allotment	7.5m x 30.0m	225m ²	22	2.53%	0.52
9.0m Front-Loaded Terrace Allotment	9.0m x 30.0m	270m ²	20	2.30%	0.68
7.5m Rear-Loaded Terrace Allotment	7.5m x 30.0m	225m ²	148	16.99%	3.72
9.0m Rear-Loaded Terrace Allotment	9.0m x 30.0m	270m ²	74	8.50%	2.53
Sub Total			264	30.31%	7.45
30m Deep Detached Allotment (18 dw/ha)					
10.0m Villa Allotment	10.0m x 30.0m	300m ²	241	27.67%	7.72
12.5m Premium Villa Allotment	12.5m x 30.0m	375m ²	157	18.03%	6.33
14.0m Courtyard Allotment	14.0m x 30.0m	420m ²	157	18.03%	7.05
16.0m Premium Courtyard Allotment	16.0m x 30.0m	480m ²	36	4.13%	2.04
Sub Total			591	67.85%	23.14
Sub Total Residential Allotment Yield			855	98.16%	30.59
Additional Allotment Type					
Medium Density Site	-	-	3	0.34%	2.68
Primary School	-	-	1	0.11%	7.00
Local Linear Park	-	-	3	0.34%	4.66
Local and Neighbourhood Recreation Park	-	-	4	0.46%	1.38
Stormwater Management	-	-	5	0.57%	2.52
Total Additional Allotment Type Yield			16	1.84%	18.24
Total Allotments			871	100.00%	48.83
Maximum Potential Residential Dwellings					
Optional Duplex Allotments	-	-	12	-	-
Medium Density Sites (site density 40 dw/ha)	-	-	107	-	-
Sub Total Maximum Potential Residential Dwellings			119	-	-
Total Maximum Potential Residential Dwellings			974	-	33.27
Maximum Potential Net Residential Density					19.31 dw/ha
Land Budget Summary Precinct 1 Summary	Summary				
Land Use Type					
Residential					
Low Density Residential			23.14	31.51%	
Low-Medium Density Residential			7.45	10.15%	
Medium Density Site			2.68	3.65%	
Sub Total			33.27	45.31%	
Open Space					
Local Linear Parks			4.66	6.35%	
Local and Neighbourhood Recreation Parks			1.38	1.88%	
Linear Pockets (incl. Earth Mounds and Pedestrian Links)			1.80	2.45%	
Stormwater Management			2.52	3.43%	
Sub Total			10.36	14.11%	
Education					
Primary School			7.00	9.53%	
Sub Total			7.00	9.53%	
Services and Street Network					
Trunk and Neighbourhood Connectors			8.80	11.98%	
Local Street Network			14.00	19.07%	
Sub Total			22.80	31.05%	
Proposed Total			73.43	100.00%	
Existing road reserve			-2.80	-	
Proposed total area less existing road reserve			70.63	-	



Legend:

- Site boundary
- Precinct boundary
- Stage boundary
- Existing road reserve
- 400m neighbourhood park catchment



Yield Summary Precinct 1	Typical Dimensions	Typical Area	Stage 1A		Stage 1B		Stage 2		Stage 3		Stage 4		Stage 5		Stage 6		Stage 7		Stage 8		Stage 9		Stage 10		Stage 11		Stage 12		Total	
			No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)	No. of Lots	Area (ha)
Residential Allotment Type																														
30m Deep Attached (Terrace) Allotment (30 dw/ha)																														
7.5m Front-Loaded Terrace Allotment	7.5m x 30.0m	225m ²	5	0.11	0	0.00	3	0.07	8	0.18	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	6	0.16	0	0.00	0	0.00	22	0.52
9.0m Front-Loaded Terrace Allotment	9.0m x 30.0m	270m ²	4	0.12	0	0.00	2	0.06	8	0.30	2	0.06	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	4	0.14	0	0.00	0	0.00	20	0.68
7.5m Rear-Loaded Terrace Allotment	7.5m x 30.0m	225m ²	0	0.00	0	0.00	4	0.10	0	0.00	0	0.00	13	0.35	0	0.00	14	0.38	21	0.57	5	0.11	10	0.33	81	1.88	0	0.00	148	3.72
9.0m Rear-Loaded Terrace Allotment	9.0m x 30.0m	270m ²	0	0.00	0	0.00	2	0.08	0	0.00	0	0.00	10	0.33	0	0.00	8	0.23	10	0.30	2	0.07	4	0.18	38	1.34	0	0.00	74	2.53
Sub Total			9	0.23	0	0.00	11	0.31	16	0.48	2	0.06	23	0.68	0	0.00	22	0.61	31	0.87	7	0.18	24	0.81	119	3.22	0	0.00	264	7.45
30m Deep Detached Allotment (18 dw/ha)																														
10.0m Villa Allotment	10.0m x 30.0m	300m ²	7	0.23	0	0.00	11	0.41	23	0.75	19	0.58	29	0.91	0	0.00	46	1.39	26	0.89	44	1.39	12	0.43	24	0.74	0	0.00	241	7.72
12.5m Premium Villa Allotment	12.5m x 30.0m	375m ²	18	0.70	0	0.00	4	0.15	12	0.54	33	1.30	7	0.26	0	0.00	31	1.19	14	0.58	16	0.67	5	0.23	17	0.71	0	0.00	157	6.33
14.0m Courtyard Allotment	14.0m x 30.0m	420m ²	14	0.64	0	0.00	24	1.06	13	0.59	23	1.03	8	0.39	0	0.00	16	0.70	24	1.10	16	0.68	3	0.15	16	0.71	0	0.00	157	7.05
16.0m Premium Courtyard Allotment	16.0m x 30.0m	480m ²	2	0.10	0	0.00	7	0.39	2	0.12	10	0.52	4	0.27	0	0.00	6	0.38	5	0.26	0	0.00	0	0.00	0	0.00	0	0.00	36	2.04
Sub Total			41	1.67	0	0.00	46	2.01	50	2.00	85	3.43	48	1.83	0	0.00	99	3.66	69	2.83	76	2.74	20	0.81	57	2.16	0	0.00	591	23.14
Sub Total Residential Allotment Yield			50	1.90	0	0.00	57	2.32	66	2.48	87	3.49	71	2.51	0	0.00	121	4.27	100	3.70	83	2.92	44	1.62	176	5.38	0	0.00	855	30.59
Additional Allotment Type																														
Medium Density Site	-	-	0	0.00	1	0.69	0	0.00	0	0.00	1	0.82	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	1	1.17	0	0.00	0	0.00	3	2.68
Primary School	-	-	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	1	7.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	1	7.00
Local Linear Park	-	-	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	0	0.00	1	2.05	1	1.70	1	0.91	0	0.00	0	0.00	0	0.00	3	4.66
Local and Neighbourhood Recreation Park	-	-	0	0.00	0	0.00	0	0.00	1	0.61	0	0.00	1	0.10	0	0.00	0	0.00	1	0.50	0	0.00	0	0.00	1	0.17	0	0.00	4	1.38
Stormwater Management	-	-	1	0.61	0	0.00	0	0.00	0	0.00	0	0.00	1	0.48	0	0.00	0	0.00	0	0.00	1	0.41	1	0.29	0	0.00	1	0.73	5	2.52
Total Additional Allotment Type Yield			1	0.61	1	0.69	0	0.00	1	0.61	1	0.82	2	0.58	1	7.00	0	0.00	2	2.55	2	2.11	3	2.37	1	0.17	1	0.73	16	18.24
Total Allotments			51	2.51	1	0.69	57	2.32	67	3.09	88	4.31	73	3.09	1	7.00	121	4.27	102	6.25	85	5.03	47	3.99	177	5.55	1	0.73	871	48.83
Maximum Potential Residential Dwellings																														
Optional Duplex Allotments	-	-	0	-	0	-	3	-	3	-	0	-	3	-	0	-	3	-	0	-	0	-	0	-	0	-	0	-	12	-
Medium Density Sites (site density 40 dw/ha)	-	-	0	-	29	-	0	-	0	-	32	-	0	-	0	-	0	-	0	-	0	-	46	-	0	-	0	-	107	-
Sub Total Maximum Potential Residential Dwellings			0	-	29	-	3	-	3	-	32	-	3	-	0	-	3	-	0	-	0	-	46	-	0	-	0	-	119	-
Total Maximum Potential Residential Dwellings			50	1.90	29	0.69	60	2.32	69	2.48	119	4.31	74	2.51	0	0.00	124	4.27	100	3.70	83	2.92	90	2.79	176	5.38	0	0.00	974	33.27
Maximum Potential Net Residential Density																														
			16.45 dw/ha		37.18 dw/ha		14.78 dw/ha		15.58 dw/ha		20.91 dw/ha		19.68 dw/ha		N/A		21.34 dw/ha		15.38 dw/ha		21.50 dw/ha		22.67 dw/ha		20.58 dw/ha		N/A		19.31 dw/ha	
Land Budget Summary Precinct 1																														
Land Use Type	Stage 1A		Stage 1B		Stage 2		Stage 3		Stage 4		Stage 5		Stage 6		Stage 7		Stage 8		Stage 9		Stage 10		Stage 11		Stage 12		Total			
	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%	Area (ha)	%		
Residential																														
Low Density Residential	1.67	37.36%	0.00	0.00%	2.01	49.51%	2.00	42.11%	3.43	45.79%	1.83	39.10%	0.00	0.00%	3.66	57.01%	2.83	30.93%	2.74	44.12%	0.81	10.83%	2.16	22.67%	0.00	0.00%	23.14	31.51%		
Low-Medium Density Residential	0.23	5.15%	0.00	0.00%	0.31	7.64%	0.48	10.11%	0.06	0.80%	0.68	14.53%	0.00	0.00%	0.61	9.50%	0.87	9.51%	0.18	2.90%	0.81	10.83%	3.22	33.79%	0.00	0.00%	7.45	10.15%		
Medium Density Site	0.00	0.00%	0.69	88.46%	0.00	0.00%	0.00	0.00%	0.82	10.95%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	1.17	15.64%	0.00	0.00%	0.00	0.00%	2.68	3.65%		
Sub Total	1.90	42.51%	0.69	88.46%	2.32	57.14%	2.48	52.21%	4.31	57.54%	2.51	53.63%	0.00	0.00%	4.27	66.51%	3.70	40.44%	2.92	47.02%	2.79	37.30%	5.38	56.45%	0.00	0.00%	33.27	45.31%		
Open Space																														
Local Linear Parks	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	2.05	22.40%	1.70	27.38%	0.91	12.17%	0.00	0.00%	0.00	0.00%	4.66	6.35%		
Local and Neighbourhood Recreation Parks	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.61	12.84%	0.00	0.00%	0.10	2.14%	0.00	0.00%	0.00	0.00%	0.50	5.46%	0.00	0.00%	0.00	0.00%	0.17	1.78%	0.00	0.00%	1.38	1.88%		
Linear Pockets (incl. Earth Mounds and Pedestrian Links)	0.19	4.25%	0.09	11.54%	0.32	7.88%	0.00	0.00%	0.32	4.27%	0.10	2.14%	0.00	0.00%	0.08	1.25%	0.00	0.00%	0.00	0.00%	0.56	7.49%	0.14	1.47%	0.00	0.00%	1.80	2.45%		
Stormwater Management	0.61	13.65%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.48	10.26%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.41	6.60%	0.29	3.88%	0.00	0.00%	0.73	100.00%	2.52	3.43%		
Sub Total	0.80	17.90%	0.09	11.54%	0.32	7.88%	0.61	12.84%	0.32	4.27%	0.68	14.53%	0.00	0.00%	0.08	1.25%	2.55	27.87%	2.11	33.98%	1.76	23.53%	0.31	3.25%	0.73	100.00%	10.36	14.11%		
Education																														
Primary School	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	7.00	91.15%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	7.00	9.53%
Sub Total	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	7.00	91.15%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	0.00	0.00%	7.00	9.53%
Services and Street Network																														
Trunk and Neighbourhood Connectors	0.82	18.34%	0.00	0.00%	0.00	0.00%	0.32	6.74%	1.80	24.03%	0.44	9.40%	0.68	8.85%	0.61	9.50%	0.60	6.56%	0.24	3.86%	2.31	30.88%	0.98	10.28%</						

Appendix 2. LCC Desired Standards of Service

Water Network Desired Standards of Service (DSS)

Parameter	Criteria																												
Water demand																													
Average Day Demand (ADD)	On demand areas - 190 L/EP/d. Based on 165 L/EP/d residential consumption + allowance for leakage/losses (25 L/EP/d).																												
	Constant flow areas -190 L/EP/d. Based on 165 L/EP/d residential consumption + allowance for leakage/losses (25 L/EP/d).																												
Peaking factors	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Category</th> <th style="width: 15%;">MDMM/AD</th> <th style="width: 15%;">MD/AD</th> <th style="width: 15%;">PH/AD</th> </tr> </thead> <tbody> <tr> <td>Residential detached</td> <td style="text-align: center;">1.3</td> <td style="text-align: center;">1.7</td> <td style="text-align: center;">3.1</td> </tr> <tr> <td>Residential attached</td> <td style="text-align: center;">1.3</td> <td style="text-align: center;">1.6</td> <td style="text-align: center;">2.6</td> </tr> <tr> <td>Rural residential / Constant flow</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1</td> <td style="text-align: center;">1.5</td> </tr> <tr> <td>Commercial</td> <td style="text-align: center;">1.2</td> <td style="text-align: center;">1.3</td> <td style="text-align: center;">2.0</td> </tr> <tr> <td>Industry</td> <td style="text-align: center;">1.2</td> <td style="text-align: center;">1.3</td> <td style="text-align: center;">1.7</td> </tr> <tr> <td>Parks / Open space</td> <td style="text-align: center;">1.2</td> <td style="text-align: center;">1.3</td> <td style="text-align: center;">1.7</td> </tr> </tbody> </table>	Category	MDMM/AD	MD/AD	PH/AD	Residential detached	1.3	1.7	3.1	Residential attached	1.3	1.6	2.6	Rural residential / Constant flow	1	1	1.5	Commercial	1.2	1.3	2.0	Industry	1.2	1.3	1.7	Parks / Open space	1.2	1.3	1.7
Category	MDMM/AD	MD/AD	PH/AD																										
Residential detached	1.3	1.7	3.1																										
Residential attached	1.3	1.6	2.6																										
Rural residential / Constant flow	1	1	1.5																										
Commercial	1.2	1.3	2.0																										
Industry	1.2	1.3	1.7																										
Parks / Open space	1.2	1.3	1.7																										
Guidance Note: Peaking factors are to be applied to the residential component of demand, i.e. 165 L/EP/d. Leakage /loss levels will remain constant throughout all demand categories and should only be appended after any peaking escalation has occurred.																													
System planning																													
Bulk supply and reticulation	3 days of MDMM. Reservoirs to have a net positive inflow and capable of continuous operation and not fall below the emergency level. 3 days of MD. Reservoirs should not fall below the emergency level. 5 days of AD. Reservoirs should fill from empty to full.																												
Service pressures																													
Minimum operating pressure at PH	On demand areas – 22m at the property boundary based on reservoir at minimum operating level (MOL). MOL defined as 15% of storage height or top of emergency storage.																												
	Constant flow areas – 10m at the property boundary based on reservoir at minimum operating level (MOL) MOL defined as 15% of storage height or top of emergency storage.																												
Maximum operating pressure	80 m at the property boundary based on the reservoir at TWL																												
Target maximum operating pressure	55 m at the property boundary based on the reservoir level at TWL																												
Fire fighting																													
System pressure	On demand areas	12 m minimum at property boundary																											
	Constant flow areas	no fire service provided																											
Fire flow	Constant flow areas	no fire service provided																											
	Rural Residential	7.5 L/s for 2 hrs																											
	Rural Commercial / Industrial	15 L/s for 2 hrs																											
	Residential	15 L/s for 2 hrs																											
	Commercial & Industrial	30 L/s for 4 hrs																											
	Special risk / hazard	to be advised by Logan City Council (LCC)																											
Background demand	2/3 PH (as per DEWS requirements)																												
Reservoir level	Minimum Operating Level (MOL)																												

Water quality			
Drinking water quality	Drinking water to comply with the NHMRC Australian Drinking Water Guidelines		
Reservoir storage			
Ground level storage capacity	3 (MD - MDMM) + (Emergency storage) Emergency Storage = 4 hr MDMM demand in zone or 0.5 ML whichever is greater.		
Elevated storage capacity Guidance Note: In-line pressure booster pumping without high-level storage shall be considered where satisfactory pressures can be provided by gravity flow during low demand periods or booster failure can be mitigated to an acceptable level (risk assessment required) and where there is no other feasible means of providing adequate pressure.	6 (PH - 1/12 MDMM) + minimum firefighting reserve. <i>Fire Fighting reserve =</i> > 4800EP: <ul style="list-style-type: none"> rural residential 0.11 ML industry 0.54 ML otherwise 0.22 ML < 4800 EP: <ul style="list-style-type: none"> rural residential 0.05 ML industry 0.43 ML otherwise 0.11 ML 		
Pumping capacity			
Pump supplying a ground level reservoir	MDMM over 20 hrs		
Pump supplying an elevated reservoir	$(6PH - \text{operating volume}) / (6 \times 3600)$ <i>Operating volume =</i> Elevated reservoir capacity - fire fighting reserve		
Standby pump capacity	To match duty, except where more than one duty pump or as determined by risk assessment.		
Reticulation booster pumps/pumped system	PH + fire flow		
Pipeline assessment & design			
Main capacity	Raw water mains & trunk feeding ground level reservoir: MDMM for a gravity supply and MDMM over 20hrs for a pumped supply Trunk Mains feeding elevated reservoir: capacity of pumps: Reticulation Mains: PH + fire flow.		
Mains size Guidance Note: New CF areas are not permitted by LCC.	Constant flow areas - where mains terminate in short runs such as cu- de-sacs minimum sizes that may be acceptable are: DN 63 up to 150 m from main DN 80 up to 350 m from main On demand areas - minimum reticulation main 100mm in residential areas and 150mm in commercial and industrial areas.		
Friction default value	Existing Infrastructure	Future Infrastructure	
	Colebrook White k values (mm)		
	Pipe Material	Pipeline Age (years)	The design shall be conducted to achieve less than the following head losses: a) 5 m head/km for \leq DN 150 (CIOD) or \leq DN 180 (ISO). b) 3 m head/km for \geq DN 200 (CIOD) or \geq DN 250 (ISO). c) Head loss shall be calculated using computer models or hydraulic formulas.
		< 10 10 to 25 > 25	
Asbestos Cement	0.15 0.3 0.3		
Plastic (UPVC, MDPE, Hobas, etc)	0.06 0.06 0.15		
MSCL/DICL	0.3 0.3 0.6		
CICL	0.3 0.3 0.6		
Maximum velocity	2.5 m/s At peak hour for trunk mains and at peak hour including fire flow for reticulation.		

Standpipe and Hydrant Filling Points	
Hydraulic model	<p><u>Planning Scenario</u> All designated and planned standpipes and hydrant filling points are to be modelled at either anticipated flowrates or recorded flows from SCADA or field test (hourly patterns).</p>
	<p><u>Operational Scenario</u> Operational scenario to be modelled at 15 min time steps to highlight actual likely impacts on network.</p>
<p><u>Augmentation</u> – In general significant network augmentations would not be considered prudent to support new hydrant filling points. Alternate strategies such as relocation or management of hydrant filling point flows (while maintaining suitable service levels) should be considered to maintain DSS. Suitable service levels should be agreed with Council's Water Business & Customer Management team.</p>	

WASTEWATER NETWORK DSS

Parameter	Criteria	
Sewage load		
ADWF	165 L/EP/day	
PDWF	Use actual flow data; or $d \times 165 \quad \text{L/EP/d or}$ $d \times 0.00191 \times EP \quad \text{L/s}$ <p>Where:</p> $d = 0.01(\log A)^4 - 0.19(\log A)^3 + 1.4(\log A)^2 - 4.66\log A + 7.57$ <p><i>d</i> = dry weather peaking factor <i>A</i> = gross plan area of development catchment, in hectares Refer to WSAA Sewerage Code of Australia; Part 1 Planning and Design</p>	
Overflow Frequency Standard for assessment of existing networks and planning and design of augmentations for existing networks This standard is only to be used by Council and their consultants	Master Planning; <ul style="list-style-type: none"> Manholes: Maximum of 1 overflow per year Sewer designated outlet: Maximum of 2 overflows per year Detailed Planning; <ul style="list-style-type: none"> Acceptable network overflow frequency standard to be determined using a risk or effects based approach. The standard is to be determined in consultation with Council. 	
PWWF For planning and design of wastewater networks servicing greenfield development This standard is to be used by developers, Council and their consultants	Residential	1000 L/EP/d (6.1xADWF)
	Non-residential	840 L/EP/d (5xADWF)
	High density residential (minimum 3 storey development)	PDWF+0.2 L/s/Ha
	Common Effluent Drainage	660 L/EP/d (4xADWF)
Gravity sewer design		
Flow equation	Colebrook White to be used for all applications – design and modelling	
Pipe roughness general	Colebrook White $k = 1.5\text{mm}$	
Maximum velocity @ PWWF	3 m/s	
Depth of flow @ PWWF - Existing	Up to 1m below MH surface level and no spillage through overflow structures	
Depth of flow @ PWWF - Proposed/ new sewers	75% of pipe depth	
Depth of flow @ PDWF – Existing and new sewers	Maximum 60% of pipe depth	
Minimum shear stress	Minimum grades are to be based on achieving self-cleansing shear stress of 1.6 Pa at 75% of PDWF. Self-cleansing shear stress should be met within 5 years of constructing a pipeline in a greenfield area. The designer must consider the operational implications of not meeting self-cleansing shear over any timeframe.	

Slime Stripping shear stress

It is desirable where gradients permit to achieve slime stripping. A wall shear of 3.35Pa is required to achieve slime stripping.

Slime stripping shear should be achieved at PWWF. Where gravity mains are constructed in greenfield areas, the operational implications of not meeting slime stripping shear in the early years of growth are to be considered.

Diameter (mm)	Grades (mm, 1 in X)
150	180 (80 in last section between last manholes or to an end)
225	300
300	400

Minimum Grades are to be based on achieving Self Cleansing Shear Stress of 1.6 Pa at 75% PDWF, refer formula and figure below.

$$S_{min} = \frac{\tau}{\rho \cdot g \cdot R_p}$$

Where:

- S_{min} = Minimum Grade
- τ = Self Cleansing Shear Stress = 1.6 Pa
- τ = Slime Stripping Shear Stress = 3.85 Pa
- ρ = Density of Water = 1000 kg/m³
- g = Gravitational constant = 9.8 m²/s
- R_p = Hydraulic Radius Partial Full Pipe (m) = Wetted Perimeter / Cross sectional flow area

Minimum grades for self cleansing

375 - 1200

Note: Depth/Diameter ratio is based on flow conditions at PDWF

Gravity sewer design	
Flow criticality	<p>If the gradient of a pipeline creates super critical flow conditions consideration must be given to appropriate manhole design to ensure flow disturbances do not occur. Flow criticality is determined by the Froude number:</p> <p>Fr<1.0 sub critical Fr= 1.0 critical Fr>1.0 super critical</p> <p>Where</p> $Fr = \frac{v}{\sqrt{g D}}$ <p>v=velocity m/s g=gravity m²/s D=hydraulic depth (m)</p>
Sewerage pump stations	
Wet well operating requirements	<p>$V \text{ (kL)} = \frac{0.9 \times \text{pump rate (L/s)}}{N}$</p> <p>N</p> <p>Where N is the acceptable number of starts per hour</p> <p>Pump Rate (L/s) = capacity of the largest duty pump</p> <p>N = 12 for motors <= 15 kW N = 8 for motors 15kW - 200 kW N = 5 for motors > 200 kW</p> <p>Control levels shall be based on Table 5.1 of WSA04-2005. The minimum depth between duty start and duty off is 100mm and ideally should be 300mm or greater.</p>
Emergency storage	<p>Emergency storage volume requirement to be based on containment of 2 hours of PDWF. Where actual measured flow data is available, then volume should be based on containing 2 hrs measured PDWF provided it takes into account any future growth. Except where otherwise specified to meet the requirements of the overflow risk assessment</p> <p>If there is an overflow pipe - storage in the system is measured between the high level alarm and overflow pipe invert level.</p> <p>If there is no overflow pipe - storage is measured between the high level alarm and 300mm below the lowest upstream manhole or top of wet well.</p>
Pump capacity	<p>If PWWF <20L/s, then 2 pumps (duty/standby arrangement) shall be provided, with each pump being capable of delivering PWWF.</p> <p>If PWWF >20L/s and <200L/s, then 2 pumps (duty/duty assist arrangement) shall be provided, with each pump being sized such that the two pumps running in parallel are capable of delivering PWWF. The minimum single pump capacity shall be not less than the calculated PDWF, where PDWF is a minimum of 2.5xADWF. If calculated PDWF has a peaking factor <2.5xADWF then 2.5 shall be used.</p> <p>All pump stations with a capacity greater than 200 L/s are to be designed on a case by case basis in consultation with Logan City Council.</p> <p>Pump stations that discharge directly to a WWTP are to be designed to minimise flow variability in wet and dry weather conditions.</p>
NPSH	Refer Clause 6.4 of WSA04-2005
Guidance Note:	<p>As pump stations (PS) are typically categorised as trunk infrastructure this standard shall also apply to pump stations in RIGS networks.</p>


Rising mains	
Flow equation	Colebrook White to be used for all applications
Friction mains	<p>For preliminary design a Colebrook White Roughness (k) of 0.6 mm is to be used.</p> <p>For detailed design, roughness shall be based on velocity and pipe roughness at end of pump design life.</p> <p>However, pumps should be able to operate (not necessarily meet design flow) for Colebrook White roughness's between manufacturers specified roughness for new pipes and 0.6 mm</p>
Minimum velocity	<p>Minimum Velocity to be based on:</p> <ul style="list-style-type: none"> • achieving an absolute minimum self cleansing shear stress of 1.6 Pa at single pump flow • achieving slime stripping shear stress of 3.85 Pa at the greater of PWWF or maximum pump station pumping capacity • If slime stripping shear cannot be met with single pump flow a regular flushing regime is required to prevent slime build up. <p>The wall shear is to be calculated using the following equation:</p> $\tau = \rho \cdot g \cdot (D/4) \times (HL/L)$ <p>Where:</p> <p>τ = Wall Shear Stress (minimum of 1.6 Pa required for self cleansing)</p> <p>HL = Frictional loss over main length of L based on Colebrook White (m)</p> <p>L = Length of main (m)</p> <p>ρ = Density of Water = 1000 kg/m³</p> <p>g = Gravitational constant = 9.8 m²/s</p> <p>D = Internal Diameter of Pipe (m)</p>
Maximum velocity	<p>3.0 m/s proposed systems</p> <p>Manufacturer's specifications for new systems</p>
Max detention time	<p>Maximum time of detention in pressure main and SPS wet well is 6 hours [2 hours in wet well and 4 hours in rising main] (based on daily average flows) to minimise potential for odour / hydrogen sulphide generation. Where high retention times are likely to occur, odour / sulphide control measures will be required to the satisfaction of Logan City Council.</p> <p>(Refer WSA 07-2007-1.1 section 3.15)</p>
Reduced infiltration gravity sewers (RIGS) & NuSewers	
NuSewer	Are not permitted without Logan City Council approval
RIGS Design	Refer to SEQ WS&S D&C Code Section 6.7.2 Design Parameters
Low pressure sewers / vacuum pumps	
Low pressure sewers / vacuum pumps	Are not preferred and will only be allowed subject to approval from Logan City Council.
Private pump stations and rising mains	
Private pump stations and rising mains	Private pump stations and rising mains are permitted for single users only and no connection or sharing will be permitted without approval from Logan City Council.
Common effluent drainage	
Common effluent drainage (CED)	Not permitted without approval from Logan City Council.


Appendix 3. Riverbend sewer trunk pipeline design plans


Appendix 4. Sewer network modelling results


Gravity Mains


Northern SPS Catchment

























Central SPS Catchment



















































Northern SPS and DN100 Rising Main











Appendix 5. Water supply network modelling results

Precinct 1 - Nodes

Develop. Stage	Node ID	Peak Demand (l/s)	FF Min Pressure (m)	SF Min Pressure (m)	Surface RL (m)
Stage 1A and 1B	P1-100	0.141	59.22	51.60	43.00
	P1-69	0.141	52.37	45.60	49.00
	P1-70	0.141	53.67	46.10	48.50
	P1-71	0.141	51.08	44.60	50.00
	P1-72	0.141	52.33	45.60	49.00
	P1-74	0.141	53.43	46.60	48.00
	P1-75	0.141	53.42	46.60	48.00
	P1-76	0.141	53.04	46.10	48.50
	P1-77	0.141	51.15	46.10	48.50
	P1-78	0.141	54.43	46.60	48.00
	P1-79	0.141	53.70	46.60	48.00
P1-80	0.376	53.07	46.60	48.00	
Stage 1-2	P1-61	0.141	59.10	48.57	46.00
	P1-62	0.141	53.99	46.07	48.50
	P1-64	0.141	51.42	49.57	45.00
	P1-65	0.141	56.04	49.57	45.00
	P1-66	0.141	56.27	46.57	48.00
	P1-67	0.141	53.37	46.57	48.00
	P1-68	0.141	53.44	48.07	46.50
	P1-69	0.141	55.22	45.57	49.00
	P1-70	0.141	52.65	46.07	48.50
	P1-71	0.141	53.52	44.57	50.00
	P1-72	0.141	51.08	45.57	49.00
	P1-74	0.141	52.27	46.57	48.00
	P1-75	0.141	53.27	46.57	48.00
	P1-76	0.141	53.30	46.07	48.50
	P1-77	0.141	52.92	46.07	48.50
	P1-78	0.141	51.03	46.57	48.00
	P1-79	0.141	54.31	46.57	48.00
	P1-80	0.376	53.58	46.57	48.00
Stages 1-3	P1-100	0.141	52.95	51.57	43.00
	P1-57	0.141	45.29	40.05	54.50
	P1-59	0.141	49.94	45.55	49.00
	P1-60	0.141	50.97	45.55	49.00
	P1-61	0.141	54.82	48.55	46.00
	P1-62	0.141	52.38	46.05	48.50
	P1-63	0.141	48.35	42.05	52.50
	P1-64	0.141	56.17	49.55	45.00
	P1-65	0.141	56.23	49.55	45.00
	P1-66	0.141	53.40	46.55	48.00
	P1-67	0.141	53.43	46.55	48.00
	P1-68	0.141	55.15	48.05	46.50
	P1-69	0.141	52.50	45.55	49.00
	P1-70	0.141	53.40	46.05	48.50
	P1-71	0.141	51.36	44.55	50.00
	P1-72	0.141	52.27	45.55	49.00
	P1-73	0.141	51.95	45.55	49.00
	P1-74	0.141	53.19	46.55	48.00
	P1-75	0.141	53.14	46.55	48.00
	P1-76	0.141	52.79	46.05	48.50
P1-77	0.141	50.84	46.05	48.50	
P1-78	0.141	54.18	46.55	48.00	
P1-79	0.141	53.43	46.55	48.00	
P1-80	0.376	52.83	46.55	48.00	

	P1-82	0.141	46.05	40.55	54.00
	P1-85	0.141	40.12	40.05	54.50
	P1-100	0.141	56.00	51.55	43.00
Stage 1-4	P1-53	0.141	58.86	35.02	59.50
	P1-54	0.141	41.61	35.52	59.00
	P1-55	0.141	42.13	37.52	57.00
	P1-56	0.446	44.15	38.52	56.00
	P1-57	0.141	45.25	40.02	54.50
	P1-58	0.141	46.48	44.52	50.00
	P1-59	0.141	51.20	45.52	49.00
	P1-60	0.141	50.23	45.52	49.00
	P1-61	0.141	51.20	48.52	46.00
	P1-62	0.141	54.83	46.02	48.50
	P1-63	0.141	52.42	42.02	52.50
	P1-64	0.141	48.51	49.52	45.00
	P1-65	0.141	56.10	49.52	45.00
	P1-66	0.141	56.36	46.52	48.00
	P1-67	0.141	53.30	46.52	48.00
	P1-68	0.141	53.32	48.02	46.50
	P1-69	0.141	55.07	45.52	49.00
	P1-70	0.141	52.37	46.02	48.50
	P1-71	0.141	53.29	44.52	50.00
	P1-72	0.141	51.26	45.52	49.00
	P1-73	0.141	52.39	45.52	49.00
	P1-74	0.141	52.26	46.52	48.00
	P1-75	0.141	53.06	46.52	48.00
	P1-76	0.141	53.05	46.02	48.50
	P1-77	0.141	52.67	46.02	48.50
	P1-78	0.141	50.77	46.52	48.00
	P1-79	0.141	54.06	46.52	48.00
	P1-80	0.376	53.33	46.52	48.00
	P1-82	0.141	52.71	40.52	54.00
	P1-85	0.141	47.05	40.02	54.50
	P1-100	0.141	45.31	51.52	43.00
Stage 1-9	Node2_6726	0.141	55.44	51.77	42.50
	Node2_6727	0.141	57.88	54.27	40.00
	Node2_6728	0.141	62.63	58.77	35.50
	Node2_6729	0.141	64.16	60.27	34.00
	Node2_6730	0.141	63.14	59.27	35.00
	Node2_6731	0.141	62.32	58.27	36.00
	Node2_6732	0.141	59.98	56.27	38.00
	Node2_6733	0.141	53.24	49.27	45.00
	Node2_6734	0.141	53.67	49.77	44.50
	Node2_6735	0.141	49.12	45.27	49.00
	Node2_6737	0.141	58.71	55.27	39.00
	Node2_6738	0.141	58.81	55.27	39.00
	Node2_6739	0.141	56.42	52.77	41.50
	Node2_6740	0.141	59.91	56.27	38.00
	Node2_6742	0.141	60.18	56.27	38.00
	Node2_6743	0.141	60.07	56.27	38.00
	Node2_6749	0.141	59.90	56.27	38.00
	P1-2	0.000	64.06	60.27	34.00
	P1-1	0.141	62.26	58.27	36.00
	P1-3	0.141	59.96	55.77	38.50
P1-4	0.141	50.34	46.27	48.00	
P1-5	0.141	49.67	45.27	49.00	
P1-6	0.141	49.10	45.27	49.00	
P1-7	0.141	47.00	42.27	52.00	
P1-27	0.141	44.88	38.78	55.50	

P1-30	0.141	45.76	39.28	55.00
P1-31	0.141	46.01	39.28	55.00
P1-39	0.141	44.52	39.27	55.00
P1-40	0.141	44.66	39.27	55.00
P1-41	0.141	46.88	41.27	53.00
P1-42	0.141	47.58	42.27	52.00
P1-43	0.141	49.44	44.27	50.00
P1-44	0.141	52.04	46.77	47.50
P1-45	0.141	45.21	39.28	55.00
P1-46	0.141	45.98	40.28	54.00
P1-47	0.141	46.04	40.28	54.00
P1-48	0.141	43.42	37.28	57.00
P1-49	0.141	43.58	37.28	57.00
P1-50	0.141	46.75	41.28	53.00
P1-51	0.141	44.11	37.78	56.50
P1-52	0.141	44.41	39.28	55.00
P1-53	0.141	41.53	34.79	59.50
P1-54	0.141	42.13	35.29	59.00
P1-55	0.141	44.22	37.29	57.00
P1-56	0.446	45.15	38.29	56.00
P1-57	0.141	46.23	39.80	54.50
P1-58	0.141	51.01	44.30	50.00
P1-59	0.141	49.97	45.30	49.00
P1-60	0.141	51.00	45.30	49.00
P1-61	0.141	54.57	48.30	46.00
P1-62	0.141	52.10	45.80	48.50
P1-63	0.141	48.21	41.80	52.50
P1-64	0.141	55.83	49.30	45.00
P1-65	0.141	56.12	49.30	45.00
P1-66	0.141	52.96	46.31	48.00
P1-67	0.141	53.01	46.31	48.00
P1-68	0.141	54.75	47.81	46.50
P1-69	0.141	52.00	45.31	49.00
P1-70	0.141	52.87	45.82	48.50
P1-71	0.141	50.97	44.30	50.00
P1-72	0.141	52.13	45.30	49.00
P1-73	0.141	52.09	45.30	49.00
P1-74	0.141	52.53	46.32	48.00
P1-75	0.141	52.51	46.32	48.00
P1-76	0.141	52.13	45.83	48.50
P1-77	0.141	50.26	45.83	48.50
P1-78	0.141	53.53	46.33	48.00
P1-79	0.141	52.81	46.32	48.00
P1-80	0.376	52.22	46.32	48.00
P1-81	0.141	48.74	44.27	50.00
P1-82	0.141	46.93	40.29	54.00
P1-84	0.000	54.49	47.28	47.00
P1-85	0.141	45.17	39.79	54.50
P1-88	0.141	49.33	45.27	49.00
P1-93	0.141	54.41	49.27	45.00
P1-94	0.576	45.44	39.28	55.00
P1-95	0.141	45.56	39.28	55.00
P1-97	0.141	45.36	40.28	54.00
P1-99	0.141	47.96	40.78	53.50
P1-100	0.141	58.38	51.32	43.00
P1-200	0.000	47.98	40.78	53.50
Node2_4889	0.000	66.45	60.13	34.00
Node2_4918	0.000	56.84	50.13	44.00
Node2_6591	0.000	62.84	56.13	38.00

Stages 1-11
(Ultimate)

Node2_6726	0.141	56.82	51.61	42.50
Node2_6727	0.141	59.38	54.11	40.00
Node2_6728	0.141	64.22	58.61	35.50
Node2_6729	0.141	65.67	60.11	34.00
Node2_6730	0.141	64.60	59.11	35.00
Node2_6731	0.141	63.67	58.11	36.00
Node2_6732	0.141	61.34	56.11	38.00
Node2_6733	0.141	54.61	49.11	45.00
Node2_6734	0.141	55.08	49.61	44.50
Node2_6735	0.141	50.75	45.11	49.00
Node2_6736	0.141	55.96	50.11	44.00
Node2_6737	0.141	60.88	55.11	39.00
Node2_6738	0.141	60.86	55.11	39.00
Node2_6739	0.141	58.05	52.61	41.50
Node2_6740	0.141	61.73	56.11	38.00
Node2_6741	0.141	50.93	45.11	49.00
Node2_6742	0.141	61.44	56.11	38.00
Node2_6743	0.141	61.42	56.11	38.00
Node2_6749	0.141	61.42	56.11	38.00
Node2_6812	0.000	62.81	56.13	38.00
P1-2	0.000	65.38	60.11	34.00
P1-1	0.141	63.67	58.11	36.00
P1-3	0.141	61.22	55.61	38.50
P1-4	0.141	51.61	46.11	48.00
P1-5	0.141	50.85	45.11	49.00
P1-6	0.141	50.73	45.11	49.00
P1-7	0.141	48.03	42.11	52.00
P1-9	0.000	57.84	51.13	43.00
P1-10	0.000	57.74	51.12	43.00
P1-11	0.141	57.72	51.12	43.00
P1-12	0.141	55.91	49.61	44.50
P1-13	0.141	56.65	50.12	44.00
P1-14	0.141	55.72	49.61	44.50
P1-15	0.141	54.03	48.11	46.00
P1-16	0.141	49.50	43.61	50.50
P1-17	0.141	51.58	45.12	49.00
P1-18	0.141	48.69	43.11	51.00
P1-19	0.141	45.65	40.11	54.00
P1-20	0.141	45.70	40.11	54.00
P1-21	0.141	44.83	39.11	55.00
P1-22	0.141	43.51	37.61	56.50
P1-23	0.141	43.04	37.11	57.00
P1-24	0.141	43.95	38.11	56.00
P1-25	0.141	44.94	39.11	55.00
P1-26	0.141	44.89	39.11	55.00
P1-27	0.141	44.53	38.61	55.50
P1-28	0.141	45.9	40.11	54.00
P1-29	0.141	44.89	39.11	55.00
P1-30	0.141	45.04	39.11	55.00
P1-31	0.141	45.07	39.11	55.00
P1-32	0.141	44.96	39.11	55.00
P1-33	0.141	45.95	40.11	54.00
P1-34	0.141	45.92	40.11	54.00
P1-35	0.141	46.09	40.11	54.00
P1-36	0.141	45.58	39.61	54.50
P1-37	0.141	54.27	48.11	46.00
P1-38	0.000	48.68	42.13	52.00
P1-39	0.141	45.12	39.11	55.00
P1-40	0.141	45.09	39.11	55.00

P1-41	0.141	47.03	41.11	53.00
P1-42	0.141	47.65	42.11	52.00
P1-43	0.141	49.76	44.11	50.00
P1-44	0.141	52.67	46.61	47.50
P1-45	0.141	44.98	39.11	55.00
P1-46	0.141	45.78	40.11	54.00
P1-47	0.141	45.81	40.11	54.00
P1-48	0.141	42.94	37.11	57.00
P1-49	0.141	42.93	37.10	57.00
P1-50	0.141	46.75	41.11	53.00
P1-51	0.141	43.23	37.60	56.50
P1-52	0.141	44.37	39.11	55.00
P1-53	0.141	40.26	34.60	59.50
P1-54	0.141	40.75	35.10	59.00
P1-55	0.141	42.81	37.10	57.00
P1-56	0.446	43.53	38.10	56.00
P1-57	0.141	44.43	39.60	54.50
P1-58	0.141	49.19	44.10	50.00
P1-59	0.141	48.08	45.10	49.00
P1-60	0.141	49.08	45.10	49.00
P1-61	0.141	52.68	48.10	46.00
P1-62	0.141	50.21	45.60	48.50
P1-63	0.141	46.36	41.60	52.50
P1-64	0.141	53.88	49.10	45.00
P1-65	0.141	54.14	49.10	45.00
P1-66	0.141	50.95	46.10	48.00
P1-67	0.141	50.98	46.10	48.00
P1-68	0.141	52.60	47.60	46.50
P1-69	0.141	49.92	45.10	49.00
P1-70	0.141	50.59	45.60	48.50
P1-71	0.141	49.01	44.10	50.00
P1-72	0.141	50.31	45.10	49.00
P1-73	0.141	50.38	45.10	49.00
P1-74	0.141	50.04	46.10	48.00
P1-75	0.141	50.06	46.10	48.00
P1-76	0.141	49.64	45.60	48.50
P1-77	0.141	47.75	45.60	48.50
P1-78	0.141	51.00	46.10	48.00
P1-79	0.141	50.30	46.10	48.00
P1-80	0.376	49.75	46.10	48.00
P1-81	0.141	48.98	44.11	50.00
P1-82	0.141	45.48	40.10	54.00
P1-84	0.000	53.87	47.13	47.00
P1-85	0.141	43.70	39.60	54.50
P1-86	0.000	58.35	51.63	42.50
P1-87	0.000	66.57	60.13	34.00
P1-88	0.141	50.76	45.11	49.00
P1-89	0.141	52.94	47.11	47.00
P1-90	0.637	61.52	55.61	38.50
P1-91	0.000	57.84	51.13	43.00
P1-92	0.141	55.93	49.61	44.50
P1-93	0.141	55.25	49.11	45.00
P1-94	0.576	44.91	39.11	55.00
P1-95	0.141	44.99	39.11	55.00
P1-97	0.141	45.99	40.11	54.00
P1-98	0.141	46.11	40.11	54.00
P1-99	0.141	46.55	40.61	53.50
P1-100	0.141	55.96	51.10	43.00
P1-200	0.000	47.36	40.63	53.50

Note: Each stage will be constructed separately, however certain stages were modelled concurrently where they represented the worst-case hydraulic scenario relative to the preceding stages (e.g. higher cumulative flows through the same pipework).

Precinct 1 - Pipes

Develop. Stage	Pipe ID	Diam. (mm)	SF PH Flow (L/s)	SF PH Velocity (m/s)	SF PH Headloss (m/km)
Stage 1A and 1B	P1-71.P1-69.1	100.0	0.14	0.02	0.01
	P1-69.P1-70.1	100.0	0.28	0.04	0.03
	P1-71.P1-72.1	100.0	0.00	0.00	0.00
	P1-72.P1-100.1	150.0	0.14	0.01	0.00
	P1-74.P1-75.1	100.0	0.07	0.01	0.00
	P1-76.P1-75.1	100.0	0.21	0.03	0.01
	P1-76.P1-78.1	100.0	0.49	0.06	0.07
	P1-76.P1-77.1	100.0	0.14	0.02	0.01
	P1-74.P1-79.1	100.0	0.08	0.01	0.00
	P1-79.P1-80.1	100.0	0.38	0.05	0.05
	P1-79.P1-100.1	100.0	0.59	0.08	0.10
	P1-78.P1-70.1	150.0	0.42	0.02	0.01
	P1-100.P1-78.1	150.0	0.88	0.05	0.03
MPR-N1669.P1-78.1	150.0	1.93	0.11	0.12	
Stage 1 - 2	P1-64.P1-65.1	100.0	0.22	0.03	0.02
	P1-65.P1-68.1	150.0	0.36	0.02	0.01
	P1-64.P1-66.1	100.0	0.06	0.01	0.00
	P1-66.P1-67.1	100.0	0.35	0.04	0.04
	P1-67.P1-69.1	100.0	0.23	0.03	0.02
	P1-71.P1-69.1	100.0	0.04	0.01	0.00
	P1-69.P1-70.1	100.0	0.33	0.04	0.04
	P1-67.P1-68.1	100.0	0.26	0.03	0.02
	P1-61.P1-64.1	100.0	0.14	0.02	0.01
	P1-61.P1-62.1	100.0	0.00	0.00	0.00
	P1-62.P1-66.1	100.0	0.14	0.02	0.01
	P1-71.P1-72.1	100.0	0.18	0.02	0.01
	P1-72.P1-100.1	150.0	0.32	0.02	0.00
	P1-74.P1-75.1	100.0	0.08	0.01	0.00
	P1-76.P1-75.1	100.0	0.23	0.03	0.02
	P1-76.P1-78.1	100.0	0.51	0.06	0.08
	P1-76.P1-77.1	100.0	0.14	0.02	0.01
	P1-74.P1-79.1	100.0	0.06	0.01	0.00
	P1-79.P1-80.1	100.0	0.38	0.05	0.05
	P1-79.P1-100.1	100.0	0.57	0.07	0.09
P1-78.P1-70.1	150.0	1.23	0.07	0.05	
P1-70.P1-68.1	150.0	0.76	0.04	0.02	
P1-100.P1-78.1	150.0	1.04	0.06	0.04	
MPR-N1669.P1-78.1	150.0	2.91	0.16	0.27	
Stages 1-3	P1-82.P1-73.1	150.0	0.14	0.01	0.00
	P1-73.P1-72.1	150.0	0.42	0.02	0.01
	P1-64.P1-65.1	100.0	0.35	0.04	0.04
	P1-65.P1-68.1	150.0	0.49	0.03	0.01
	P1-64.P1-66.1	100.0	0.09	0.01	0.00
	P1-66.P1-67.1	100.0	0.48	0.06	0.07
	P1-67.P1-69.1	100.0	0.20	0.03	0.01
	P1-71.P1-69.1	100.0	0.26	0.03	0.02
	P1-69.P1-70.1	100.0	0.61	0.08	0.10
	P1-67.P1-68.1	100.0	0.42	0.05	0.06
	P1-61.P1-64.1	100.0	0.30	0.04	0.03
	P1-57.P1-60.1	100.0	0.05	0.01	0.00
	P1-60.P1-59.1	100.0	0.14	0.02	0.01
	P1-60.P1-61.1	100.0	0.23	0.03	0.02
P1-61.P1-62.1	100.0	0.08	0.01	0.00	

	P1-63.P1-62.1	100.0	0.04	0.00	0.00
	P1-62.P1-66.1	100.0	0.25	0.03	0.02
	P1-57.P1-63.1	100.0	0.19	0.02	0.01
	P1-63.P1-71.1	100.0	0.29	0.04	0.03
	P1-71.P1-72.1	100.0	0.17	0.02	0.01
	P1-72.P1-100.1	150.0	0.74	0.04	0.02
	P1-74.P1-75.1	100.0	0.13	0.02	0.01
	P1-76.P1-75.1	100.0	0.27	0.03	0.03
	P1-76.P1-78.1	100.0	0.56	0.07	0.09
	P1-76.P1-77.1	100.0	0.14	0.02	0.01
	P1-74.P1-79.1	100.0	0.01	0.00	0.00
	P1-79.P1-80.1	100.0	0.38	0.05	0.05
	P1-79.P1-100.1	100.0	0.53	0.07	0.08
	P1-78.P1-70.1	150.0	1.80	0.10	0.10
	P1-70.P1-68.1	150.0	1.05	0.06	0.04
	P1-100.P1-78.1	150.0	1.40	0.08	0.07
	P1-85.P1-73.1	100.0	0.14	0.02	0.01
	MPR-N1669.P1-78.1	150.0	3.90	0.22	0.46
Stages 1 - 4	P1-55.P1-54.1	150.0	0.13	0.01	0.00
	P1-54.P1-53.1	150.0	0.21	0.01	0.00
	P1-55.P1-56.1	150.0	0.01	0.00	0.00
	P1-53.P1-82.1	150.0	0.35	0.02	0.01
	P1-82.P1-73.1	150.0	0.49	0.03	0.01
	P1-54.P1-85.1	100.0	0.06	0.01	0.00
	P1-73.P1-72.1	150.0	0.83	0.05	0.03
	P1-56.P1-57.1	100.0	0.04	0.01	0.00
	P1-56.P1-58.1	150.0	0.42	0.02	0.01
	P1-58.P1-65.1	150.0	0.56	0.03	0.01
	P1-64.P1-65.1	100.0	0.20	0.03	0.01
	P1-65.P1-68.1	150.0	0.90	0.05	0.03
	P1-64.P1-66.1	100.0	0.21	0.03	0.02
	P1-66.P1-67.1	100.0	0.65	0.08	0.12
	P1-67.P1-69.1	100.0	0.29	0.04	0.03
	P1-71.P1-69.1	100.0	0.36	0.05	0.04
	P1-69.P1-70.1	100.0	0.79	0.10	0.17
	P1-67.P1-68.1	100.0	0.50	0.06	0.07
	P1-61.P1-64.1	100.0	0.27	0.03	0.02
	P1-57.P1-60.1	100.0	0.04	0.00	0.00
	P1-60.P1-59.1	100.0	0.14	0.02	0.01
	P1-60.P1-61.1	100.0	0.25	0.03	0.02
	P1-61.P1-62.1	100.0	0.12	0.01	0.01
	P1-63.P1-62.1	100.0	0.03	0.00	0.00
	P1-62.P1-66.1	100.0	0.29	0.04	0.03
	P1-57.P1-63.1	100.0	0.22	0.03	0.02
	P1-63.P1-71.1	100.0	0.32	0.04	0.04
	P1-71.P1-72.1	100.0	0.10	0.01	0.01
	P1-72.P1-100.1	150.0	1.08	0.06	0.04
	P1-74.P1-75.1	100.0	0.18	0.02	0.01
	P1-76.P1-75.1	100.0	0.32	0.04	0.03
	P1-76.P1-78.1	100.0	0.60	0.08	0.10
	P1-76.P1-77.1	100.0	0.14	0.02	0.01
	P1-74.P1-79.1	100.0	0.04	0.00	0.00
	P1-79.P1-80.1	100.0	0.38	0.05	0.05
	P1-79.P1-100.1	100.0	0.48	0.06	0.07
P1-78.P1-70.1	150.0	2.47	0.14	0.18	
P1-70.P1-68.1	150.0	1.54	0.09	0.08	
P1-100.P1-78.1	150.0	1.70	0.10	0.09	
P1-85.P1-73.1	100.0	0.20	0.03	0.01	
MPR-N1669.P1-78.1	150.0	4.91	0.28	0.71	

Stages 1-9	MP-P03639 (Node2_6726.Node2_6732.1)	100.0	0.02	0.00	0.00
	MP-P03646 (Node2_6728.Node2_6729.1)	150.0	0.29	0.02	0.00
	MP-P03643 (Node2_6729.Node2_6730.1)	150.0	0.33	0.02	0.00
	MP-P03644 (Node2_6730.Node2_6731.1)	150.0	0.47	0.03	0.01
	MP-P03645 (Node2_6732.Node2_6729.1)	100.0	0.10	0.01	0.00
	MP-P03637 (Node2_6733.Node2_6726.1)	100.0	0.25	0.03	0.02
	MP-P03641 (Node2_6742.Node2_6743.1)	100.0	0.25	0.03	0.02
	MP-P03642 (Node2_6743.Node2_6731.1)	100.0	0.15	0.02	0.01
	P1-1.P1-2.1	150.0	0.00	0.00	0.00
	P1-1.Node2_6731.1	150.0	0.76	0.04	0.02
	P1-3.P1-1.1	150.0	0.90	0.05	0.03
	P1-3.Node2_6742.1	100.0	0.25	0.03	0.02
	P1-5.P1-3.1	150.0	1.29	0.07	0.06
	P1-5.P1-4.1	100.0	0.78	0.10	0.16
	Node2_6742.P1-4.1	100.0	0.15	0.02	0.01
	P1-4.Node2_6733.1	100.0	0.49	0.06	0.07
	Node2_6743.Node2_6732.1	100.0	0.26	0.03	0.02
	Node2_6733.Node2_6734.1	100.0	0.10	0.01	0.00
	Node2_6734.Node2_6735.1	100.0	0.27	0.03	0.02
	Node2_6734.Node2_6727.1	100.0	0.22	0.03	0.02
	Node2_6726.Node2_6749.1	100.0	0.13	0.02	0.01
	Node2_6727.Node2_6749.1	100.0	0.08	0.01	0.00
	Node2_6749.Node2_6728.1	100.0	0.07	0.01	0.00
	Node2_6728.Node2_6740.1	150.0	0.22	0.01	0.00
	Node2_6740.Node2_6738.1	150.0	0.08	0.00	0.00
	Node2_6737.Node2_6738.1	150.0	0.14	0.01	0.00
	P1-6.Node2_6735.1	100.0	0.48	0.06	0.07
	Node2_6738.Node2_6739.1	100.0	0.20	0.03	0.01
	Node2_6739.Node2_6727.1	100.0	0.00	0.00	0.00
	Node2_6739.P1-6.1	100.0	0.34	0.04	0.04
	P1-7.P1-5.1	150.0	2.21	0.13	0.15
	Node2_6735.P1-88.1	100.0	0.89	0.11	0.20
	P1-27.P1-95.1	150.0	0.14	0.01	0.00
	P1-30.P1-31.1	150.0	1.00	0.06	0.04
	P1-31.P1-99.1	150.0	1.14	0.06	0.05
	P1-7.P1-39.1	150.0	3.39	0.19	0.35
	P1-39.P1-44.1	150.0	1.03	0.06	0.04
	P1-39.P1-40.1	150.0	2.50	0.14	0.18
	P1-40.P1-43.1	100.0	0.09	0.01	0.00
	P1-40.P1-41.1	150.0	2.55	0.14	0.19
	P1-41.P1-42.1	100.0	0.06	0.01	0.00
	P1-44.P1-43.1	100.0	0.57	0.07	0.09
	P1-44.P1-93.1	150.0	0.60	0.03	0.01
	P1-81.P1-50.1	100.0	0.88	0.11	0.20
	P1-46.P1-47.1	100.0	0.67	0.09	0.12
	P1-47.P1-50.1	100.0	0.22	0.03	0.02
	P1-45.P1-46.1	100.0	0.48	0.06	0.07
	P1-42.P1-46.1	100.0	1.01	0.13	0.25
P1-43.P1-42.1	100.0	0.81	0.10	0.17	
P1-41.P1-45.1	150.0	2.63	0.15	0.20	
P1-45.P1-48.1	150.0	3.25	0.18	0.29	
P1-47.P1-48.1	100.0	1.03	0.13	0.26	
P1-48.P1-49.1	150.0	4.42	0.25	0.50	

	P1-50.P1-97.1	100.0	0.80	0.10	0.17
	P1-52.P1-51.1	100.0	1.08	0.14	0.29
	P1-49.P1-51.1	100.0	1.08	0.14	0.28
	P1-51.P1-55.1	100.0	2.30	0.29	1.10
	P1-55.P1-54.1	150.0	1.40	0.08	0.06
	P1-54.P1-53.1	150.0	0.27	0.02	0.00
	P1-49.P1-53.1	150.0	3.48	0.20	0.33
	P1-55.P1-56.1	150.0	5.53	0.31	0.75
	P1-53.P1-82.1	150.0	3.90	0.22	0.40
	P1-82.P1-73.1	150.0	4.04	0.23	0.43
	P1-54.P1-85.1	100.0	1.27	0.16	0.38
	P1-73.P1-72.1	150.0	5.59	0.32	0.77
	P1-56.P1-57.1	100.0	2.30	0.29	1.10
	P1-56.P1-58.1	150.0	3.67	0.21	0.36
	P1-58.P1-65.1	150.0	3.81	0.22	0.38
	P1-64.P1-65.1	100.0	0.01	0.00	0.00
	P1-65.P1-68.1	150.0	3.95	0.22	0.41
	P1-64.P1-66.1	100.0	1.08	0.14	0.29
	P1-66.P1-67.1	100.0	2.53	0.32	1.31
	P1-67.P1-69.1	100.0	0.92	0.12	0.22
	P1-71.P1-69.1	100.0	1.94	0.25	0.81
	P1-69.P1-70.1	100.0	3.00	0.38	1.79
	P1-67.P1-68.1	100.0	1.75	0.22	0.67
	P1-61.P1-64.1	100.0	0.93	0.12	0.22
	P1-57.P1-60.1	100.0	0.93	0.12	0.22
	P1-60.P1-59.1	100.0	0.14	0.02	0.01
	P1-60.P1-61.1	100.0	1.22	0.15	0.35
	P1-61.P1-62.1	100.0	0.42	0.05	0.06
	P1-63.P1-62.1	100.0	0.74	0.09	0.15
	P1-62.P1-66.1	100.0	1.31	0.17	0.40
	P1-57.P1-63.1	100.0	1.51	0.19	0.52
	P1-63.P1-71.1	100.0	0.91	0.12	0.21
	P1-71.P1-72.1	100.0	0.89	0.11	0.20
	P1-72.P1-100.1	150.0	4.84	0.27	0.59
	P1-74.P1-75.1	100.0	0.79	0.10	0.16
	P1-76.P1-75.1	100.0	0.93	0.12	0.22
	P1-76.P1-78.1	100.0	1.21	0.15	0.35
	P1-76.P1-77.1	100.0	0.14	0.02	0.01
	P1-74.P1-79.1	100.0	0.65	0.08	0.12
	P1-79.P1-80.1	100.0	0.38	0.05	0.05
	P1-79.P1-100.1	100.0	0.13	0.02	0.01
	P1-78.P1-70.1	150.0	8.98	0.51	1.82
	P1-70.P1-68.1	150.0	5.83	0.33	0.83
Stages 1-11 (Ultimate)	MP-P03434 (Node2_4918.Node2_4914.1)	300.0	9.99	0.14	0.08
	MP-P03445 (Node2_4918.P1-91.1)	300.0	0.00	0.00	0.00
	MP-P04187 (P1-91.P1-38.1)	250.0	0.00	0.00	0.00
	MP-P03764 (Node2_6591.P1-86.1)	375.0	0.00	0.00	0.00
	MP-P03639 (Node2_6726.Node2_6732.1)	100.0	0.08	0.01	0.00
	MP-P03646 (Node2_6728.Node2_6729.1)	150.0	0.53	0.03	0.01
	MP-P03643 (Node2_6729.Node2_6730.1)	150.0	0.30	0.02	0.00
	MP-P03644 (Node2_6730.Node2_6731.1)	150.0	0.16	0.01	0.00
	MP-P03645 (Node2_6732.Node2_6729.1)	100.0	0.08	0.01	0.00
	MP-P03637 (Node2_6733.Node2_6726.1)	100.0	0.10	0.01	0.00

MP-P03641 (Node2_6742.Node2_6743.1)	100.0	0.04	0.01	0.00
MP-P03642 (Node2_6743.Node2_6731.1)	100.0	0.08	0.01	0.00
P1-86.P1-87.1	250.0	0.00	0.00	0.00
P1-1.P1-2.1	150.0	0.00	0.00	0.00
P1-1.Node2_6731.1	150.0	0.06	0.00	0.00
P1-3.P1-1.1	150.0	0.20	0.01	0.00
P1-3.Node2_6742.1	100.0	0.10	0.01	0.01
P1-5.P1-3.1	150.0	0.44	0.03	0.01
P1-5.P1-4.1	100.0	0.23	0.03	0.02
Node2_6742.P1-4.1	100.0	0.08	0.01	0.00
P1-4.Node2_6733.1	100.0	0.01	0.00	0.00
Node2_6743.Node2_6732.1	100.0	0.02	0.00	0.00
Node2_6741.P1-7.1	150.0	0.72	0.04	0.02
Node2_6733.Node2_6734.1	100.0	0.24	0.03	0.02
Node2_6734.Node2_6735.1	100.0	0.33	0.04	0.04
Node2_6734.Node2_6727.1	100.0	0.05	0.01	0.00
Node2_6726.Node2_6749.1	100.0	0.11	0.01	0.00
Node2_6727.Node2_6749.1	100.0	0.11	0.01	0.01
Node2_6749.Node2_6728.1	100.0	0.15	0.02	0.01
Node2_6728.Node2_6740.1	150.0	0.81	0.05	0.03
Node2_6740.Node2_6738.1	150.0	0.95	0.05	0.03
Node2_6737.Node2_6738.1	150.0	1.57	0.09	0.08
Node2_6736.P1-90.1	150.0	1.91	0.11	0.11
Node2_6736.P1-6.1	100.0	0.46	0.06	0.06
P1-6.Node2_6735.1	100.0	0.36	0.05	0.04
Node2_6738.Node2_6739.1	100.0	0.48	0.06	0.07
Node2_6739.Node2_6727.1	100.0	0.30	0.04	0.03
Node2_6739.P1-6.1	100.0	0.04	0.00	0.00
Node2_6736.P1-89.1	150.0	1.31	0.07	0.06
P1-7.P1-5.1	150.0	0.82	0.05	0.03
Node2_6735.P1-88.1	100.0	0.11	0.01	0.01
MP-P03764 (P1-9.P1-200.1)	375.0	6.72	0.06	0.01
P1-10.P1-11.1	250.0	16.71	0.34	0.55
P1-11.P1-13.1	250.0	0.28	0.01	0.00
P1-13.P1-17.1	250.0	0.14	0.00	0.00
P1-16.P1-22.2	150.0	1.74	0.10	0.10
P1-22.P1-23.1	150.0	2.20	0.12	0.14
P1-23.P1-24.1	100.0	0.61	0.08	0.11
P1-24.P1-25.1	100.0	0.06	0.01	0.00
P1-25.P1-21.1	100.0	0.64	0.08	0.11
P1-23.P1-27.1	150.0	1.44	0.08	0.07
P1-27.P1-26.1	100.0	0.11	0.01	0.00
P1-24.P1-26.1	100.0	0.53	0.07	0.08
P1-26.P1-29.1	100.0	0.28	0.04	0.03
P1-25.P1-28.1	100.0	0.44	0.06	0.06
P1-28.P1-29.1	100.0	0.28	0.04	0.03
P1-29.P1-30.1	100.0	0.42	0.05	0.05
P1-27.P1-95.1	150.0	1.41	0.08	0.07
P1-30.P1-31.1	150.0	0.97	0.05	0.03
P1-32.P1-31.1	100.0	0.19	0.02	0.01
P1-31.P1-99.1	150.0	1.02	0.06	0.04
P1-32.P1-36.1	100.0	0.22	0.03	0.02
P1-32.P1-33.1	100.0	0.55	0.07	0.09
P1-28.P1-34.1	100.0	0.02	0.00	0.00
P1-34.P1-33.1	100.0	0.45	0.06	0.06
P1-33.P1-35.1	100.0	0.24	0.03	0.02
P1-35.P1-98.1	150.0	2.43	0.14	0.17

P1-35.P1-37.1	150.0	2.82	0.16	0.22
P1-12.P1-14.1	150.0	3.59	0.20	0.34
P1-14.P1-16.1	150.0	2.48	0.14	0.18
P1-14.P1-15.1	100.0	0.97	0.12	0.24
P1-37.P1-15.1	100.0	0.95	0.12	0.23
P1-15.P1-19.1	100.0	0.79	0.10	0.16
P1-18.P1-19.1	100.0	0.11	0.01	0.01
P1-19.P1-21.1	100.0	0.76	0.10	0.15
P1-15.P1-18.1	100.0	0.99	0.13	0.25
P1-16.P1-22.1	100.0	0.59	0.08	0.10
P1-18.P1-20.1	100.0	0.74	0.09	0.15
P1-20.P1-21.1	100.0	0.02	0.00	0.00
P1-20.P1-34.1	100.0	0.58	0.07	0.10
P1-11.P1-92.1	150.0	12.02	0.68	3.13
P1-12.P1-37.1	150.0	3.91	0.22	0.40
MP-P04187 (P1-38.Node2_4889.1)	250.0	0.00	0.00	0.00
P1-7.P1-39.1	150.0	0.18	0.01	0.00
P1-39.P1-44.1	150.0	1.93	0.11	0.11
P1-39.P1-40.1	150.0	1.60	0.09	0.08
P1-40.P1-43.1	100.0	0.26	0.03	0.02
P1-40.P1-41.1	150.0	1.72	0.10	0.09
P1-41.P1-42.1	100.0	0.03	0.00	0.00
P1-44.P1-43.1	100.0	1.08	0.14	0.29
P1-44.P1-93.1	150.0	3.15	0.18	0.27
P1-81.P1-50.1	100.0	0.81	0.10	0.17
P1-46.P1-47.1	100.0	0.12	0.02	0.01
P1-47.P1-50.1	100.0	0.63	0.08	0.11
P1-45.P1-46.1	100.0	0.31	0.04	0.03
P1-42.P1-46.1	100.0	0.57	0.07	0.09
P1-43.P1-42.1	100.0	0.68	0.09	0.13
P1-41.P1-45.1	150.0	1.55	0.09	0.08
P1-45.P1-48.1	150.0	1.72	0.10	0.09
P1-47.P1-48.1	100.0	0.61	0.08	0.11
P1-48.P1-49.1	150.0	2.19	0.12	0.14
P1-50.P1-97.1	100.0	0.04	0.00	0.00
P1-52.P1-51.1	100.0	0.70	0.09	0.13
P1-49.P1-51.1	100.0	0.48	0.06	0.07
P1-51.P1-55.1	100.0	1.03	0.13	0.26
P1-55.P1-54.1	150.0	0.70	0.04	0.02
P1-54.P1-53.1	150.0	0.03	0.00	0.00
P1-49.P1-53.1	150.0	1.57	0.09	0.08
P1-55.P1-56.1	150.0	2.50	0.14	0.18
P1-53.P1-82.1	150.0	1.46	0.08	0.07
P1-82.P1-73.1	150.0	1.32	0.07	0.06
P1-54.P1-85.1	100.0	0.53	0.07	0.08
P1-73.P1-72.1	150.0	1.57	0.09	0.08
P1-56.P1-57.1	100.0	0.87	0.11	0.19
P1-56.P1-58.1	150.0	1.18	0.07	0.05
P1-58.P1-65.1	150.0	1.04	0.06	0.04
P1-64.P1-65.1	100.0	0.33	0.04	0.04
P1-65.P1-68.1	150.0	0.57	0.03	0.01
P1-64.P1-66.1	100.0	0.15	0.02	0.01
P1-66.P1-67.1	100.0	0.16	0.02	0.01
P1-67.P1-69.1	100.0	0.01	0.00	0.00
P1-71.P1-69.1	100.0	0.39	0.05	0.05
P1-69.P1-70.1	100.0	0.24	0.03	0.02
P1-67.P1-68.1	100.0	0.03	0.00	0.00
P1-61.P1-64.1	100.0	0.04	0.00	0.00

P1-57.P1-60.1	100.0	0.37	0.05	0.05
P1-60.P1-59.1	100.0	0.14	0.02	0.01
P1-60.P1-61.1	100.0	0.09	0.01	0.00
P1-61.P1-62.1	100.0	0.01	0.00	0.00
P1-63.P1-62.1	100.0	0.30	0.04	0.03
P1-62.P1-66.1	100.0	0.15	0.02	0.01
P1-57.P1-63.1	100.0	0.35	0.04	0.04
P1-63.P1-71.1	100.0	0.09	0.01	0.00
P1-71.P1-72.1	100.0	0.62	0.08	0.11
P1-72.P1-100.1	150.0	0.81	0.05	0.02
P1-74.P1-75.1	100.0	0.00	0.00	0.00
P1-76.P1-75.1	100.0	0.15	0.02	0.01
P1-76.P1-78.1	100.0	0.43	0.05	0.06
P1-76.P1-77.1	100.0	0.14	0.02	0.01
P1-74.P1-79.1	100.0	0.14	0.02	0.01
P1-79.P1-80.1	100.0	0.38	0.05	0.05
P1-79.P1-100.1	100.0	0.65	0.08	0.12
P1-78.P1-70.1	150.0	0.56	0.03	0.01
P1-70.P1-68.1	150.0	0.46	0.03	0.01
P1-9.Node2_4918.1	250.0	9.99	0.20	0.21
MP-P03764 (P1-84.Node2_6842.1)	375.0	6.72	0.06	0.01
MP-P03764 (P1-86.P1-9.1)	375.0	0.00	0.00	0.00
P1-88.P1-7.1	100.0	0.05	0.01	0.00
P1-89.Node2_6741.1	150.0	0.86	0.05	0.03
P1-88.P1-89.1	100.0	0.30	0.04	0.03
P1-90.Node2_6737.1	150.0	1.71	0.10	0.09
P1-90.P1-11.1	150.0	4.26	0.24	0.54
MP-P03445 (P1-91.Node2_6812.1)	300.0	0.00	0.00	0.00
P1-92.P1-12.1	150.0	7.64	0.43	1.36
P1-93.P1-81.1	100.0	0.95	0.12	0.23
P1-92.P1-93.1	150.0	4.24	0.24	0.54
P1-95.P1-30.1	150.0	0.70	0.04	0.02
P1-95.P1-94.1	150.0	0.58	0.03	0.01
P1-97.P1-52.1	100.0	0.84	0.11	0.18
P1-98.P1-36.1	150.0	1.35	0.08	0.06
P1-98.P1-97.1	150.0	0.94	0.05	0.03
P1-99.P1-36.1	150.0	1.43	0.08	0.07
P1-99.P1-55.1	150.0	2.31	0.13	0.17
P1-100.P1-78.1	150.0	0.01	0.00	0.00
P1-85.P1-73.1	100.0	0.39	0.05	0.05
MPR-N1669.P1-78.1	150.0	0.00	0.00	0.00
MP-P03764 (P1-200.P1-84.1)	375.0	6.72	0.06	0.01
P1-200.P1-99.1	150.0	0.00	0.00	0.00

Note: Each stage will be constructed separately, however certain stages were modelled concurrently where they represented the worst-case hydraulic scenario relative to the preceding stages (e.g. higher cumulative flows through the same pipework).

Node ID's

