



NOTE ROAD TANKER MUST BE ABLE TO DRIVE IN FORWARD DIRECTION TO CLEAR TANK AREA IN EMERGENCY






PLANS AND DOCUMENTS referred to in the PDA DEVELOPMENT APPROVAL

Approval no: DEV2016/773
Date: 18 October 2016



- NOTE: 1) SECURITY FENCE ONLY REQUIRED IF LPG TANK IN PUBLIC PLACE
- 2) REFER TO SECURITY FENCE SPECIFICATION SHEET FOR MORE DETAIL
- 3) CHAIN MESH FENCE AROUND TANK TO BE SECURITY FENCE MIN 1800MM HIGH WITH 3 STRANDS OF BARBED WIRE.
- 4) ENTRY GATE TO BE OUTWARDLY OPENING



1						NOTES		SCALE	NTS	DATE	PROJECT				
								DRAWN	JMC	24/08/12	TITLE				
								CHKD			SITE TANK COMPOUND PLAN 1 BY 4.2KL				
								APPRD			BOLLARD VEHICLE PROTECTION				
								FILE LOCATION							
NO.	DATE	REVISION DESCRIPTION			BY	APP	THIS DRAWING IS THE PROPERTY OF ORIGIN ENERGY PTY LTD AND IS NOT TO BE COPIED OR USED WITHOUT ITS WRITTEN PERMISSION			DRAWN IN MILLIMETERS DO NOT SCALE		SHEET 1 of 1	SHT SIZE A1	DRAWING No.	REV